

Real-time Experimental Implementation of Predictive Control Schemes in a Small-scale Pasteurization Plant

A. Rosich and C. Ocampo-Martinez

Abstract This chapter proposes three closed-loop control topologies based on model predictive control (MPC) for a small-scale pasteurization plant. The topologies are designed taking into account the role of the predictive controller within the loop: (i) as supervisor control for the computation of the references for regulatory controllers, (ii) as unique controller within the closed loop, and (iii) acting simultaneously as supervisor and regulatory controllers together with other regulatory controllers. All control designs have been applied in real time to a test bench station then experimental results are both presented and discussed. The main advantages and drawbacks for each topology are presented for the regulation of the temperature of the output product while the energy consumption of the overall system is minimised.

1 Introduction

Along the last decades, model-based predictive control (MPC) has had a significant impact on industrial control engineering. Its implementation in process industry is justified by its capabilities of handling multi-variable control problems in a natural form, while taking into account actuator limitations and other physical and operational constraints [8, 20]. Given the computational burden associated to the optimization problem solved online when an MPC controller is implemented, the use of this control technique was preferred for control architectures formed by two levels:

A. Rosich

Flanders Mechatronics Technology Centre, Celestijnenlaan 300, 3001 Leuven, Belgium, e-mail: arosich@fmtc.be

C. Ocampo-Martinez

Automatic Control Department, Universitat Politècnica de Catalunya, Institut de Robòtica i Informàtica Industrial (CSIC-UPC), Llorens i Artigas, 4-6, 08028 Barcelona, Spain, e-mail: cocampo@iri.upc.edu

the former, as a supervisory/management level, where set-points for regulatory controllers at the lower level are computed, and the latter, as the proper regulatory level, where the control actions are applied to the dynamical system. Notice that the regulatory controllers attempt to hide the non-linear behaviours of the systems, allowing the supervisory controller to use a simpler control-oriented model [21]. Thus, MPC controllers, acting as supervisory ones, are based then on those simpler models and hence their associated optimization problems get less computational burden (see, e.g., [6, 17] and references therein).

Nevertheless, relevant technological advances during the last years make possible the real-time implementation of MPC controllers based on more complex and large dynamical models. Therefore, several possibilities arise when implementing real-time predictive controllers for industrial processes. The possible topologies can be such as the aforementioned two-level schemes, where the MPC acts as a supervisory controller, topologies where the MPC is the unique controller within the closed loop, and topologies where there is a convenient combination of the MPC controller with a twofold function and *classical* regulatory controllers (such as PIDs), interacting altogether.

On the other hand, a pasteurization system involves typical behaviours of industrial processes, where considering complex dynamical models with nonlinearities imply important challenges when a suitable controller should be designed. In that sense, some previous modelling approaches and control schemes have been already proposed. The so called *divide-and-conquer* technique for modelling the system is applied in [9], where the input-output mathematical model of the system is obtained from the decomposition of the plant in functional subsystems. Other non-linear models from the whole system and/or some subsystems are obtained in [1, 12]. Regarding its control, in [5] it is proposed a scheme based on PID with Smith Predictor in order to compensate delays when some temperatures are regulated. In [10], a Dynamic Matrix Control (DMC) is designed and implemented using the system models proposed in [9], where the delay and the energy reduction of the system were not improved. The regulation of both water and milk temperatures by using MPC is recently reported in [16], where transient behaviours have been suitably handled with respect to other control techniques such as cascade generic model control.

According to the previous discussions, this chapter performs the design and implementation of three control topologies based on MPC, where the temperature of the output product in a small-scale pasteurization plant is regulated while the energy consumption required to this end is simultaneously reduced. Therefore, the main contribution of this chapter is not only the suitable design of controllers and topologies in order to satisfy the control objectives fulfilling system constraints, but also the real-time experimental implementation of the those MPC-based topologies in the real system and the analysis of the performance results in order to highlight the advantages and disadvantages for each topology. This analysis aims at motivating the use of MPC controllers interacting within the existing industrial topologies, where it is well known the hegemony of the PID controllers.

The mathematical models of the pasteurization plant are properly obtained from the experimental data [13], but the deep description of the system identification




Fig. 1 Pasteurization plant diagram.

procedures for the corresponding subsystems is out of the scope of this chapter. None of the models previously reported in the literature were considered for the study performed in this chapter since the real pilot plant considered here is quite different with respect to those used in [1,9,16], among others. Final results where the energy consumption comparison is performed are taken into account with respect to a control scheme based only on PID controllers properly tuned by using well-known existing tools [2,4,19]. In any case, these PID controllers have been accurately tuned by using the available tools in MATLAB[®], achieving a proper response and avoiding the unfair comparison between topologies based on the possibly wrong PID tunings.

The remainder of the chapter is structured as follows. In Section 2, the pasteurization plant test bench is described. Section 3 presents the general statement of the MPC problems considered in this chapter. Besides, the mathematical models, control problem formulations and main experimental results for each one of the three proposed topologies are presented and discussed. Section 4 performs the discussion of the results presented throughout the chapter. Finally, in Section 5 the main conclusions are drawn.

2 System Description

A process plant trainer for control purposes is used in this chapter as a real benchmark to test the different proposed control topologies. Specifically, the small-scale pasteurization plant PCT23 MKII from Armfield is used [3]. Only those parts of the system that are relevant to the chapter are described in this section (see Fig. 1).

The system emulates an industrial high-temperature short-time (HTST) pasteurization process. In this process, the goal is to heat and keep the product, which is usually a liquid, at a predetermined temperature for a minimum time, typically for bacteriological purposes. This is achieved by circulating the heated liquid through a holding tube that delays the product stream.

A water heating unit is available in order to provide the necessary heat to the product. This unit consists of a water pump that circulates the hot water through a heat exchanger, and a hot water tank equipped with a temperature sensor (T_2) and an electrical resistor. The water heat is transferred to the product inside the first phase of the heat exchanger. A temperature sensor (T_3) at the heat exchanger outlet is used to ensure that the product has gained the desired temperature. The product is always pumped at a constant flow velocity in order to guarantee that it remains inside the holding tube at a constant pasteurization temperature (adiabatic phase of the process) for the minimum required time. With this end in view, a PID controller is implemented to regulate the product flow by means of a pump (feeding the product into the plant) and a flow meter located before the holding tube. This control loop will be considered fixed and out of the study carried out in this chapter. A temperature sensor (T_1) at the output of the holding tube is used to monitor the product temperature after the pasteurization process. Finally, the product is cooled in the second phase of the heat exchanger, where residual heat is transferred to the inlet product.

In summary, from a control point of view, the pasteurization plant can be seen as a multiple-input and multiple-output (MIMO) system with electric heater power, P , and water pump speed, N , as inputs, and temperatures, T_1 , T_2 , and T_3 as outputs. The control objectives are twofold: *i*) the temperature T_1 must follow a predefined profile (tracking control problem), and *ii*) the energy consumption should be minimized.

It is considered that the pasteurization plant will be operated around the working point defined by

$$\begin{aligned} P^o &= 290 \text{ W}, & N^o &= 65 \%, & T_1^o &= 55.5^\circ\text{C}, \\ T_2^o &= 66^\circ\text{C}, & T_3^o &= 56^\circ\text{C}, \end{aligned} \quad (1)$$

which will be used to obtain the linear models required throughout the chapter. The design and simulation of the controllers have been performed in MATLAB[®] R2012b by using Tomlab Optimization Software [7] in an Intel Xeon CPU E31225 - 4 cores, 3.10 GHz and 4 GB RAM. The discretization of all dynamics as well as the implementation of the MPC controllers for experimentation were performed using a sampling time of 1 s. In particular, the dynamical model of the pump N was obtained by selecting a lower sampling time (0.5 s) given the fast dynamics shown by this element compared with the remainder processes.

3 Predictive Control Schemes

3.1 MPC Problem Statement

Given that the proposed controllers consider dynamical models around the working point (1), they are expressed in the discrete-time state-space linear form

$$\mathbf{x}(k+1) = \mathbf{A}\mathbf{x}(k) + \mathbf{B}\mathbf{u}(k), \quad (2a)$$

$$\mathbf{y}(k) = \mathbf{C}\mathbf{x}(k), \quad (2b)$$

where $\mathbf{x} \in \mathcal{X} \subseteq \mathbb{R}^{n_x}$, $\mathbf{u} \in \mathcal{U} \subseteq \mathbb{R}^{n_u}$ and $\mathbf{y} \in \mathcal{Y} \subseteq \mathbb{R}^{n_y}$ correspond to the vector of system states, the vector of input signals and the vector of measured outputs, respectively, and $k \in \mathbb{Z}_+$ denotes the discrete time. \mathbf{A} , \mathbf{B} and \mathbf{C} are the system matrices of suitable dimensions. In the sequel, identified models obtained as transfer functions are conveniently expressed by their equivalent controllable realizations in state space as in (2). Moreover, let¹

$$\hat{\mathbf{u}}(k) \triangleq (\mathbf{u}(0|k), \dots, \mathbf{u}(H_p - 1|k)) \quad (3)$$

be the sequence² of input signals over a fixed-time prediction horizon H_p . Notice that (3) depends on the initial condition $\mathbf{x}(0|k) \triangleq \mathbf{x}(k)$. Therefore, the design of the different MPC controllers for the proposed control topologies/schemes in this chapter is based on Problem 1.

Problem 1 (MPC Design). The MPC design is based on the solution of the open-loop optimisation problem (OOP)

$$\min_{\{\hat{\mathbf{u}}(k) \in \mathcal{U}^{H_p}, \hat{\boldsymbol{\xi}}(k) \in \mathbb{R}^{H_p}\}} J(\mathbf{x}(k), \hat{\mathbf{u}}(k), \hat{\boldsymbol{\xi}}(k)), \quad (4a)$$

subject to

$$\mathbf{x}(i+1|k) = \mathbf{A}\mathbf{x}(i|k) + \mathbf{B}\mathbf{u}(i|k), \quad \forall i \in [0, H_p - 1], \quad (4b)$$

$$\mathbf{y}(i|k) = \mathbf{C}\mathbf{x}(i|k), \quad \forall i \in [0, H_p - 1], \quad (4c)$$

$$\mathbf{x}(k) \in \mathbb{R}^{n_x}, \quad \forall k, \quad (4d)$$

$$\mathbf{u}(i|k) \in \mathcal{U}, \quad \forall i \in [0, H_p - 1], \quad (4e)$$

$$\mathbf{G}_1\mathbf{y}(i|k) + \mathbf{G}_2\xi(i|k) \leq \mathbf{g}, \quad \forall i \in [0, H_p - 1], \quad (4f)$$

where $J(\cdot) : \mathcal{U}^{n_u H_p} \times \mathbb{R}^{H_p} \mapsto \mathbb{R}$ in (4a) is the cost function, H_p denotes the *prediction horizon* and \mathbf{G}_1 , \mathbf{G}_2 and \mathbf{g} are matrices of suitable dimensions. More-

¹ Here, $m(k+i|k)$ denotes the prediction of the variable m at time $k+i$ performed at k . For instance, $x(k+i|k)$ denotes the prediction of the system state, starting from its initial condition $\mathbf{x}(0|k) = \mathbf{x}(k)$.

² In the sequel, the notation $\hat{\mathbf{z}}$ means a sequence of vectorial elements of suitable dimensions.

over, $\xi \in \mathbb{R}$ is the *slack* variable for softening the output constraints (4f), and $\hat{\xi}(k) \triangleq (\xi(0|k), \dots, \xi(H_p - 1|k)) \in \mathbb{R}^{H_p}$. Notice that, in this chapter, expression in (4d) means the unconstrained nature of the system states. Assuming that the OOP (4) is feasible, i.e., $\mathbf{u}(k) \neq \emptyset$, there will be an optimal solution for the sequence of control inputs

$$\mathbf{u}(k)^* \triangleq (\mathbf{u}(0|k)^*, \mathbf{u}(1|k)^*, \dots, \mathbf{u}(H_p - 1|k)^*), \quad (5)$$

and then, according to the receding horizon philosophy, $\mathbf{u}^*(0|k)$ is applied to the system, while the whole process is repeated for the next time instant $k \in \mathbb{Z}_+$. \square

The following subsections present and discuss three closed-loop control schemes based on different roles of the MPC controllers wherein the main control objectives needs to be accomplished. Aspects such as the model used, the controller design and the corresponding experimental results are explained for each considered topology.

3.2 Topology 1: MPC as a Supervisory Controller

The pasteurization plant described in Section 2 can be *simply* controlled by using a PID-based control scheme [15, 18, 22]. A typical approach to track the temperature T_1 is to implement two PID controllers in cascade [3]. The inner control loop, denoted here as PID_{T_3} , regulates T_3 by manipulating the pump velocity, N , whereas the outer loop, denoted here as PID_{T_1} provides the reference for the inner-loop controller. On the other side, another control loop, denoted here as PID_{T_2} is typically implemented to regulate the temperature of the water heating unit T_2 . The PID_{T_2} controller manipulates the power of the electrical heater, P , in order to maintain the temperature T_2 at a certain constant and high value in order to guarantee that enough energy can be transferred to the product. Hence, no energy saving is considered.

In this section, this standard PID-based configuration is used. Nevertheless, the reference T_2^r , provided to regulate the temperature T_2 , is supervised by an MPC (see Fig. 2) with the objective of saving energy. For the sake of space and because it does not involve any additional difficulty, the implementation of the PID controllers is not here presented. Instead, the chapter is focused on the supervisory MPC design.

3.2.1 System Identification and Control-oriented Model

To accomplish the proposed control configuration, suitable models of the pasteurization plant are needed. In particular, two transfer functions are identified. These transfer functions relate the measured outputs T_1 and T_2 to their corresponding input references, T_1^r and T_2^r . By applying parametric identification methods (mainly based on least squares) to different model structures [14], the following transfer functions are obtained:




Fig. 2 Topology 1: MPC as a supervisory controller.

$$\frac{T_1(z)}{T_1^r(z)} = \frac{0.0008008}{z^{30} - 1.963z^{29} + 0.9639z^{28}} \quad (6)$$

and

$$\frac{T_2(z)}{T_2^r(z)} = \frac{0.00358z}{z^2 - 1.937z + 0.9406}, \quad (7)$$

where z is the z -transform variable. Observe that the transfer function (6) has order 30 because the transportation delay induced by the holding tube. In addition, it is worth noting that, since the PID control loops are considered in the plant modelling, the two input/output pairs can be decoupled.

Models (6) and (7) are validated with real data from the pasteurization plant obtaining satisfactory results. In Fig. 3 a comparison between the real system behaviour and model-obtained temperatures is depicted.

3.2.2 Control Problem Setup

In order to design the corresponding MPC, the constraints and the cost function in Problem 1 should be defined. For the proper system operation, T_2 must be always greater than T_1 . According to the performed experiments, this temperature difference between T_2 and T_1 should be greater than $D = 11.8^\circ\text{C}$. The value of D is considered as a design parameter, which was determined by iterative simulations in order to have a safety temperatures difference taking into account the variations given by the devices dynamics and signal noises. Given that the system is operated around the working point (1), this difference can be conveniently adapted through a soft constraint of the form

$$T_2(k) - T_1(k) \geq D + \xi(k), \quad (8)$$




Fig. 3 Responses from the models (6)-(7) and comparison with real data.

where $\xi \in \mathbb{R}$ allows to avoid infeasibility of the OOP in (4). On the other hand, looking at the energy consumption of the actuators, the water pump consumes 35 VA for flows between 100-300 ml/min [23], while the heater resistor consumes about 300 W. Therefore, the minimization of the energy consumption is done through the heater resistor since its consumption is significantly greater than the energy consumption of the pump. Hence, T_2^r should be minimized. Finally, the minimization of the slew rate, $\Delta T_2^r(k) \triangleq T_2^r(k) - T_2^r(k-1)$, is also considered in order to reduce oscillations in T_2 . Thus, the OOP (4) for this topology is defined as

$$\min_{\{\hat{\mathbf{T}}_2^r(k), \hat{\xi}(k)\}} \left\| \hat{\mathbf{T}}_2^r(k) \right\|_{\mathbf{W}_1}^2 + \left\| \hat{\Delta \mathbf{T}}_2^r(k) \right\|_{\mathbf{W}_2}^2 + \left\| \hat{\xi}(k) \right\|_{\mathbf{W}_3}^2, \quad (9a)$$

subject to

$$\mathbf{x}(i+1|k) = \mathbf{A}_1 \mathbf{x}(i|k) + \mathbf{B}_1 \begin{bmatrix} T_1^r(i|k) \\ T_2^r(i|k) \end{bmatrix}, \quad (9b)$$

$$\begin{bmatrix} T_1(i|k) \\ T_2(i|k) \end{bmatrix} = \mathbf{C}_1 \mathbf{x}(i|k), \quad (9c)$$

$$T_2(i|k) - T_1(i|k) \geq D + \xi(i|k), \quad (9d)$$

for all $i \in [0, H_p - 1]$, where

$$\hat{\mathbf{T}}_2^r(k) = (\mathbf{T}_2^r(0|k), \dots, \mathbf{T}_2^r(H_p - 1|k)),$$

$$\hat{\Delta \mathbf{T}}_2^r(k) = (\Delta \mathbf{T}_2^r(0|k), \dots, \Delta \mathbf{T}_2^r(H_p - 1|k)),$$

and W_i , $i = 1, 2, 3$, are the weighting matrices needed to prioritize the different control goals within the multi-objective cost function. Notice that, in general, $\mathbf{W}_i =$




Fig. 4 Controlled temperatures, T_1 and T_2 , with Topology 1.

$\omega_i \mathbf{I}$, where \mathbf{I} is the identity matrix of suitable dimensions and $\omega_i \in \mathbb{R}$. Here, the prediction model in (9b)-(9c) is derived from (6) and (7).

The MPC controller has been implemented in MATLAB[®] and tested on the pasteurization plant. The controller has been experimentally tuned for the weight values $\omega_1 = \omega_2 = 0.1$, $\omega_3 = 10$, whereas a prediction horizon $H_p = 35$ has been set³. It should be noted that, in this case, shorter horizons degrade the closed-loop performance, while a larger horizon does not improve the results and moreover takes longer in solving the optimization problem (9). The controlled temperatures from the real plant (i.e., T_1 and T_2) are shown in Fig. 4 together with their corresponding references, where T_2^r is in this case the control variable. Observe that the MPC tries to keep T_2 as lower as possible and fulfil constraint (8) at the same time. This is particularly difficult when T_1 decreases (e.g., time $k = 1500$ s and $k = 2000$ s) since T_2 should be reduced by the MPC, accordingly. However, there is no actuator to reduce T_2 and the water tank is really cooled by dissipating the heat to the atmosphere.

3.3 Topology 2: MPC as Unique Controller

Another possibility to control the pasteurization plant is an holistic approach by means of one single MPC controller that directly operates the actuators from the system measurements (see Fig. 5).

³ In this chapter, it is supposed that the prediction horizon H_p and the control horizon H_u have the same length in order to have more degrees of freedom when computing the optimal control action at each time instant $k \in \mathbb{Z}_+$.




Fig. 5 Topology 2: MPC as unique controller.




Fig. 6 Response from the model of the holding tube.

3.3.1 System Identification and Control-oriented Model

A complete model of the pasteurization plant is needed for this topology. However, due to the complexity of the system, it is not feasible to identify the whole plant at once. Instead, the different subsystems are identified and modelled separately.

Holding tube subsystem: From a thermodynamic point of view, the holding tube can be modelled as a single-input and single-output system, where temperature T_3 is the input and temperature T_1 is the output. By experimentation, the following discrete transfer function is obtained:

$$\frac{T_1(z)}{T_3(z)} = \frac{0.2231}{z^{30} - 0.7649z^{29}}. \quad (10)$$

The measurement of T_3 has been used to validate the model. In Fig. 6, the responses of T_1 obtained by applying the same measurement of T_3 in both, the real plant and the model (10) are compared.

Hot water tank subsystem: The dynamics of the temperature T_2 in the water tank of the heating unit system are derived from first principles of thermodynamics [11]. Specifically, the following differential equations is used:




Fig. 7 Response from the model of the hot water tank.

$$c_w \frac{dT_2(t)}{dt} = P(t) - c_s F(k)(T_{out}(t) - T_{in}(t)) - k_l(T_2(t) - T_a(t)), \quad (11)$$

where c_w is the heat capacity coefficient of the water mass in the tank, P is the power provided by the electrical resistor, c_s the specific heat capacity of the water, F is the water flow given by the pump, T_{out} and T_{in} are the output and input water temperatures, k_l is the heat loss coefficient and T_a is the atmospheric temperature. Note that the water flow is proportional to the pump speed, therefore $F = \alpha_1 N$. For the sake of simplicity, it is assumed that the output water temperature is the same as the measured water tank temperature, i.e., $T_{out} = T_2$, and also that the T_{in} , which cannot be measured, is proportional to T_3 , i.e., $T_{in} = \alpha_2 T_3$. In addition, T_a is assumed to be known and constant.

The unknown parameters of (11) are properly identified (by using parametric identification based on least squares [13, 14]) and then the model is discretised and linearised around the working point in (1). The resulting discrete linear model for the hot water tank system is

$$T_2(k+1) = 9.98 \times 10^{-1} T_2(k) + 1.2 \times 10^{-4} P(k) - 4.26 \times 10^{-4} N(k) - 1.64 \times 10^{-4} T_3(k). \quad (12)$$

Temperature T_2 from both, real plant and model (12) are shown in Fig. 7. In this case, the resistor power P and pump speed N are slightly modified from the working point in (1), while input temperature T_3 is taken from the real plant.

Heat exchanger subsystem: The first phase of the heat exchanger is here modelled. For simplicity, the input product temperature is assumed to be known and constant. Therefore, the dynamics of the output product temperature, T_3 , are only directly affected by the pump speed, N . It should be noted that the temperature T_3 is indirectly affected by both T_2 and the pasteurized product temperature T_1 since this latter circulates through the second phase of the heat exchanger, which is in contact with the first phase. However, in order to keep the simplicity of the model, these side effects on T_3 are not taken into account. They can be seen as unknown disturbances.

The obtained model is represented in discrete transfer function as




Fig. 8 Response from the model of the heat exchanger.

$$\frac{T_3(z)}{N(z)} = \frac{0.01141}{z - 0.8796}. \quad (13)$$

The real and the model-predicted temperature T_3 are compared in Fig. 8.

3.3.2 Control Problem Setup

As in the Topology 1, the control objectives remain the same, remarking the priority on the reduction of the energy consumption. In this case, the management of the power dissipated by the heater resistor determines the performance of the closed-loop control. Now, the MPC controller must compute the direct control actions to the actuators while performing the tracking task with T_1 . This task implies the minimization of the tracking error $e_{T_1}(k) \triangleq T_1(k) - T_1^r(k)$, while the control actions are minimized and smoothed, and the softening of the operational constraint (8) is penalized. Thus, the OOP (4) for this topology is defined as

$$\min_{\{\hat{\mathbf{N}}(k), \hat{\mathbf{P}}(k)^T, \hat{\xi}(k)\}} \left\| \hat{\mathbf{P}}(k) \right\|_{\mathbf{W}_1}^2 + \left\| \begin{bmatrix} \Delta \hat{\mathbf{N}}(k) \\ \Delta \hat{\mathbf{P}}(k) \end{bmatrix} \right\|_{\mathbf{W}_2}^2 + \left\| \hat{\xi}(k) \right\|_{\mathbf{W}_3}^2 + \left\| \hat{e}_{T_1}(k) \right\|_{\mathbf{W}_4}^2, \quad (14a)$$

subject to

$$\mathbf{x}(i+1|k) = \mathbf{A}_2 \mathbf{x}(i|k) + \mathbf{B}_2 \begin{bmatrix} N(i|k) \\ P(i|k) \end{bmatrix}, \quad (14b)$$

$$\begin{bmatrix} T_1(i|k) \\ T_2(i|k) \end{bmatrix} = \mathbf{C}_2 \mathbf{x}(i|k), \quad (14c)$$

$$N(i|k) \in [-40, 15], \quad P(i|k) \in [-0.3, 1.3], \quad (14d)$$

$$T_2(i|k) - T_1(i|k) \geq D + \xi(i|k), \quad (14e)$$

for all $i \in [0, H_p - 1]$, where

$$\begin{aligned}\hat{\mathbf{P}}(k) &= (\mathbf{P}(0|k), \dots, \mathbf{P}(H_p - 1|k)), \\ \hat{\Delta\mathbf{N}}(k) &= (\Delta N(0|k), \dots, \Delta N(H_p - 1|k)), \\ \hat{\Delta\mathbf{P}}(k) &= (\Delta P(0|k), \dots, \Delta P(H_p - 1|k)), \\ \hat{\mathbf{e}}_{\mathbf{T}_1}(k) &= (\mathbf{e}_{\mathbf{T}_1}(0|k), \dots, \mathbf{e}_{\mathbf{T}_1}(H_p - 1|k)),\end{aligned}$$

and W_4 is the weighting matrix related to the tracking error of T_1 . Notice here that W_2 is a block-diagonal matrix, whose elements are matrices $\Omega_2 = \begin{bmatrix} \Omega_{21} & 0 \\ 0 & \Omega_{22} \end{bmatrix}$. In this case, the prediction model (14b)-(14c) comes from the merging of the equivalent controllable realizations of (10), (12) and (13). Moreover, input constraints (14d) should be stated since

- both the dead zone of the pump (which is up to 25% of its operating range) and the definition of a safety range below 80% also of its operating range (over this value some elements can deteriorate rapidly) should be taken into account⁴; and
- the heating power of the resistor, P , can take values in the range $[0, 1.6]$ kW. Notice that values in (14d) consider the working point (1).

The MPC controller was implemented with the trial-and-error weight values $\omega_1 = 2$, $\omega_{21} = 10^{-3}$, $\omega_{22} = 10^{-2}$, $\omega_3 = 10^2$, and $\omega_4 = 10^3$. Moreover, $H_p = 35$.

Results obtained by applying this topology are depicted in Fig. 9. As before, the temperature T_2 ensures enough transfer heating to the product (i.e., constraint (8) is satisfied). In addition, now the delay caused by the holding tube is compensated. On the other hand, although it is not evident in the figure, the steady-state error in T_1 is not null. This is mainly due to two reasons: *i*) the models, especially the heat exchanger model in (13), are not accurate and *ii*) the pump actuator range is limited to 80% which degrades the controller performance. It is well known that it can be corrected by using an integrator-in-series configuration but it was not implemented here due to the small amount of such error.

3.4 Topology 3: MPC and PID

The last control topology presented in this chapter is a combination of the previous ones. A PID controller, denoted as PID_{T_3} , is used to control T_3 by means of the pump speed N , whereas the MPC provides the set-point for PID_{T_3} and drives directly the electric resistor at the same time (see, Fig. 10). In this topology, it is intended that a simple PID controller is more suitable for controlling T_3 because fast dynamics are present in both the temperature T_3 and the pump speed N . Furthermore, by using PID_{T_3} controller, the effect of the unknown disturbances over T_3 are mitigated which means that the model used in the MPC becomes more accurate.

⁴ Notice that the pump speed N is given in percentage with respect to the maximal speed of the corresponding pump according to the device specifications




Fig. 9 Controlled temperatures, T_1 and T_2 , with Topology 2.




Fig. 10 Topology 3: MPC and PID.

3.4.1 System Identification and Control-oriented Model

The models used in this topology can easily be derived by combining the previous models. For instance, the dynamics of T_3 driven by T_3^r can straightforwardly be obtained by computing the corresponding PID closed-loop transfer function with (13). Therefore, no new models are needed for this topology.

3.4.2 Control Problem Setup

The control design for this topology combines an MPC coping with the regulation of P , together with PID_{T_3} that manages N but which receives its reference from the MPC controller. Given the control objectives and aforementioned operational constraints, the OOP (4) for this topology is defined as

$$\min_{\{\mathbf{P}(k) \mathbf{T}_3^r(k)^T \xi(k)\}} \|\mathbf{P}(k)\|_{\mathbf{W}_1}^2 + \|\Delta \hat{\mathbf{T}}_3^r(k)\|_{\mathbf{W}_2}^2 + \|\hat{\xi}(k)\|_{\mathbf{W}_3}^2 + \|\mathbf{e}_{T_1}(k)\|_{\mathbf{W}_4}^2, \quad (15a)$$

subject to

$$\mathbf{x}(i+1|k) = \mathbf{A}_3 \mathbf{x}(i|k) + \mathbf{B}_3 \begin{bmatrix} P_{i|k} \\ T_3^r(i|k) \end{bmatrix}, \quad (15b)$$

$$\begin{bmatrix} T_1(i|k) \\ T_2(i|k) \end{bmatrix} = \mathbf{C}_2 \mathbf{x}(i|k), \quad (15c)$$

$$P(i|k) \in [-0.3, 1.3], \quad T_3^r(i|k) \in [-2, 7], \quad (15d)$$

$$T_2(i|k) - T_1(i|k) \geq D + \xi(i|k), \quad (15e)$$

for all $i \in [0, H_p - 1]$, where

$$\Delta \hat{\mathbf{T}}_3^r(k) = (\Delta \mathbf{T}_3^r(0|k), \dots, \Delta \mathbf{T}_3^r(H_p - 1|k)),$$

and the constraints for input T_3^r are given considering a small range of variation around the system working point (1). The prediction model (15b)-(15c) is obtained for this topology by merging the controllable realizations of (10) and (12). Notice here that the induction to a smooth behaviour of T_3^r implies less oscillations of T_2 . For the implementation of this control topology with the real system, the tuning parameters are set to $\omega_1 = 10^{-5}$, $\omega_2 = 300$, $\omega_3 = 1$, $\omega_4 = 10$, and $H_p = 35$.

In Fig. 11, the temperature responses from the pasteurization plant under the control Topology 3 are shown. In this case, the delay is compensated and the null steady-state is achieved. This is because the MPC is now used to compensate the delay by providing a suitable reference to PID_{T_3} , and this in turn provides the perfect tracking in steady-state despite the model inaccuracies. Moreover, the model inaccuracies alleviation also provides a better performance in terms of T_2 . Observe that now the fluctuations in the temperature T_2 have been significantly reduced. However, as far as T_1 goes away from its working point, an undesired overshoot appears in its transient dynamics. It is also produced by the new resultant behaviour of T_2 , which also experiments bigger overshoots. This phenomena might be avoided by an accurate tuning of the cost function in (15a) (conveniently increasing the prioritization of $\Delta \hat{\mathbf{T}}_3^r$).




Fig. 11 Controlled temperatures, T_1 and T_2 , with Topology 3.

4 Results Discussion

The different proposed control topologies are here compared by means of three performance indices. The values of these indices for each topology are displayed in Table 1.

The first index is the MSE (Mean Square Error) between temperature T_1 and its reference. This index indicates how accurate the tracking is performed. In this case, Topology 1 presents the worst value. This is mainly due to the fact that the holding tube delay is not compensated. On the other hand, the disturbance effect mitigation accomplished by the PID-based control loop in Topology 3 improves the MSE in front of Topology 2.

Another performance index is the settling time for temperature T_1 . Short settling times are crucial in pasteurization processes, since all the product obtained during the settling time is rejected because it does not reach the proper temperature. Topology 1 presents again the worst result while Topology 3 is significantly better than the others. This is because Topology 3 takes advantage of the fast PID-based control loop.

Third index takes into account the energy consumption by showing the percentage of saved energy with respect to the standard approach (only PID controllers with no MPC) in which no energy saving is considered (i.e., temperature T_2 is kept at 75°C all the time). Although all topologies perform similarly, Topology 3 shows better results.

Quantitatively speaking, it would be quite risky to determine the *best* control topology from those proposed here. From the point of view of energy savings, tuning procedures for cost functions in (9a), (14a) and (15a) might improve the performance of the controllers but the design and application of tuning strategies are out of the scope of this study. On the other hand, MSE index could also be improved by

Table 1 Performance indices.

Topology	MSE	Settling time (s)	Energy saving (%)
1	0.94	250	10
2	0.53	150	11
3	0.46	70	11.5

different and accurate tuning criteria, which in turn would allow to reduce or even eliminate some overshoots in temperature dynamics.

Finally, Table 2 summarizes the main features presented by the three topologies. It is worth to highlight that Topology 2 presents some small steady-state error as a consequence of model inaccuracies. However, it is the only one that can handle both actuator constraints. From this perspective, Topology 3 can be chosen as an intermediate solution, since null steady-state error is achieved and constraints on the electrical resistor can be handled.

Table 2 Qualitative features.

Topology	Null steady-state error	Actuator constraints	
		Pump speed N	Heater power P
1	✓		
2		✓	✓
3	✓		✓

5 Conclusions

Although the pasteurization process can be perfectly accomplished by standard PID controllers, in this chapter energy saving is also claimed as a control objective, which makes the MPC approach suitable for operating the plant. Therefore, three different control topologies based on MPC have been proposed in order to study which the role of the MPC should be, i.e., MPC as a supervisor or as a regulatory controller. The study has been carried out from a practical perspective, where conclusions have been drawn from experimental data. Therefore, typical problems in real implementations have been encountered, e.g., noisy signals, models inaccuracies, hardware limitations.

Topology 1 shows a proper performance against model uncertainties because the PID controllers locally compensate the model mismatches. However, the MPC is merely used to compute the set-point for the local controllers wherein some useful dynamics for the optimality of the control objective are not used. In addition, actuator constraints can not be handled. Notice here that MPC might be suitably replaced by other optimal control techniques such as LQR. On the opposite side, an MPC

commanding the actuators directly is tested in Topology 2. In this case, the model of the plant without controllers is used in the optimization, despite the inaccuracies. This leads to a loss of optimality due to the optimal for the model differs from the optimal for the plant which, in turn, results in a loss of control performance. Finally, Topology 3 is intended so that the advantages of the two previous topologies are preserved. Therefore, Topology 3 is presented as an intermediate solution between the other two topologies, wherein a local PID controller is used together with the MPC.

According to the results discussion in Section 4, Topology 3 results to be the most convenient one. This means that the choice of a control topology is not obvious since many intermediate solutions could be possible in a real plant, where a certain number of control loops needs to be considered. Therefore, the results obtained in this work motivate and justify the need of further studies in order to determine the best control topology for a given plant.

Acknowledgements This work has been partially supported by the projects ECOCIS (Ref. DPI2013-48243-C2-1-R) and EFFINET (Ref. FP7-ICT-2011-8-31855).

References

1. P. Aadaleesan, N. Miglan, R. Sharma, and P. Saha. Nonlinear system identification using Wiener type Laguerre-Wavelet network model. *Chemical Engineering Science*, 63(15):3932 – 3941, 2008.
2. Ch. Anil and R. Padma-Sree. Tuning of PID controllers for integrating systems using direct synthesis method. *ISA Transactions*, 2015. (in press).
3. Armfield. *Process Plant trainer PTC23-MKII, Instruction Manual*, 2015.
4. K.J. Åström and B. Wittenmark. *Computer Controlled Systems: Theory and Design*. Prentice Hall, 3 ed. edition, 1996.
5. M. García-Sanz, J.C. Guillén, and J.J. Ibarrola. Robust controller design for uncertain systems with variable time delay. *Control Engineering Practice*, 9(9):961 – 972, 2001.
6. J.M. Grosso, C. Ocampo-Martinez, and V. Puig. Adaptive multilevel neuro-fuzzy model predictive control for drinking water networks. In *Proceedings of the 20th Mediterranean Conference on Control Automation (MED)*, Barcelona (Spain), July 2012.
7. K. Holmström, M. Edvall, and A. Göran. Tomlab - for large-scale robust optimization. In *Proceedings of the Nordic MATLAB Conference*, Copenhagen (Denmark), 2003.
8. D. Hrovat, S. Di Cairano, H.E. Tseng, and I.V. Kolmanovsky. The development of model predictive control in automotive industry: A survey. In *Proceedings of the IEEE International Conference on Control Applications (CCA)*, pages 295–302, Dubrovnik (Croatia), 2012.
9. J.J. Ibarrola, J.C. Guillén, J.M. Sandoval, and M. García-Sanz. Modelling of a high temperature short time pasteurization process. *Food Control*, 9(5):267 – 277, 1998.
10. J.J. Ibarrola, J.M. Sandoval, M. García-Sanz, and M. Pinzolas. Predictive control of a high temperature-short time pasteurisation process. *Control Engineering Practice*, 10(7):713 – 725, 2002.
11. M. Kaufman. *Principles of Thermodynamics*. CRC Press, 2002.
12. M.T. Khadir and J.V. Ringwood. Linear and nonlinear model predictive control design for a milk pasteurization plant. *Control and Intelligent Systems*, 31(1):1–10, 2003.
13. L. Ljung. *System Identification: Theory for the User*. Prentice Hall, 1999.
14. L. Ljung. *System Identification Toolbox, Users Guide*. The MathWorks, Inc, 2012.

15. W. M. F. Wan Mokhtar, F. S. Taip, N. Abdul Aziz, and S. B. Mohd Noor. Process control of pink guava puree pasteurization process: Simulation and validation by experiment. *International Journal on Advanced Science, Engineering and Information Technology*, 2(4):31–34, 2012.
16. S. Niamsuwan, P. Kittisupakorn, and I. M. Mujtaba. Control of milk pasteurization process using model predictive approach. *Computers & Chemical Engineering*, 66:2–11, 2014.
17. C. Ocampo-Martinez, V. Puig, J.M. Grosso, and S. Montes de Oca. *DMPC made easy*, chapter Multi-layer Decentralized Model Predictive Control of Large-Scale Networked Systems. Springer, 2013.
18. T. O’Mahony and L. Torres. A virtual control engineering laboratory based on an industrial pasteurisation process. In *Proceedings of the 7th IFAC Symposium on Advances in Control Education*, Sheffield (United Kingdom), 2006.
19. K. Pirabakaran and V.M. Becerra. Automatic tuning of PID controllers using model reference adaptive control techniques. In *Proceedings of the 27th Annual Conference of the IEEE Industrial Electronics Society (IECON)*, pages 736–740, 2001.
20. S. Joe Qin and T. Badgwell. A survey of industrial model predictive control technology. *Control Engineering Practice*, 11(7):733 – 764, 2003.
21. R. Sánchez-Pena and F. Bianchi. Model selection: From LTI to switched-LPV. In *Proceedings of the American Control Conference*, Montreal (Canada), 2012.
22. L. Torres, T. O’Mahony, and P. Kelly and B. O’Connor. Controller design and implementation on a pilot-scale pasteurisation plant. In *Proceedings of the IEE Irish Signals and Systems Conference*, Dublin (Ireland), 2005.
23. Watson-Marlow. *Peristaltic Pump Drive Units*, 2012.