

Reliability computation within an MPC health-aware framework

Jean C. Salazar^{*,*} Ramon Sarrate^{*} Fatiha Nejjari^{*}
Philippe Weber^{**} Didier Theilliol^{**}

^{*} *Research Center for Supervision, Safety and Automatic Control (CS2AC), Universitat Politècnica de Catalunya, 10 Rambla Sant Nebridi Terrassa, Spain (e-mail: {jean.salazar, ramon.sarrate, fatiha.nejjari}@upc.edu).*

^{**} *Centre de Recherche en Automatique de Nancy (CRAN), Université de Lorraine, ST - B.P. 70239 54506 Vandoeuvre-Les-Nancy, France (e-mail: philippe.weber, didier.theilliol@univ-lorraine.fr)*

Abstract: This paper presents a comparison between two different approaches for reliability consideration within a Health-Aware Control framework which takes into account system and component reliability by means of reliability importance measures. The two different approaches for reliability assessment consideration are the instantaneous reliability and the expected one. The system reliability performance under both approaches is compared in a control strategy applied to a drinking water network.

Keywords: reliability, control system, availability, health aware control, drinking water network

1. INTRODUCTION

Fault-tolerant control has been a relevant topic in control theory by decades, its objective is to allow system functioning after a fault occurrence, those faults can be in sensors or actuators (Zhang and Jiang, 2008). However, using Prognostic and Health Management (PHM) to prevent faults occurrence could be more interesting from an economical and safety point of view.

The prevention of faults occurrence in the control loop is also called Health-Aware Control (HAC). This technique uses proper on-line prognostic information of the system to modify the control actions or to change the mission objective in order to maintain a high level of system health.

Extending the operational time of the system and avoiding faults occurrence can be achieved by considering the level of system components reliability and their importance for the overall system reliability in the control algorithm (Salazar et al., 2015, 2016). Then, in over-actuated systems, it is possible to redistribute the control effort among the available actuators following the appropriate policy (Khelassi et al., 2011; Bicking et al., 2013).

In this paper, the redistribution policy is given by the reliability importance of the actuators to the overall system reliability in such way that the use of an actuator does not compromise the functioning of the system. This measure was proposed by Birnbaum (1969) and defines the amount of system reliability decay if the reliability of a component decreases to 0.

In this work, two ways of calculating and interpreting the component and system reliability are studied and discussed. The first one considers the most general definition of reliability as the probability that a component will perform its function under specified conditions and for a defined interval of time, in this case, reliability is computed at fixed intervals and is a decreasing function of time. The second one considers that a component remains fully reliable as long as it is not affected by a fault, but its expected reliability decays based on its usage (Chamseddine et al., 2014).

The proposed study is illustrated using a Drinking Water Network (DWN), where a redistribution of the control efforts among the actuators is proposed in order to improve the overall DWN reliability. DWNs are multivariable dynamic systems composed of several interconnected subsystems, such as tanks, pumps, valves, intersection nodes, water sources and consumer sectors.

Model Predictive Control (MPC) approach has proved to be an efficient technique that can predict the appropriate control actions to achieve optimal performance according to physical constraints and multiobjective cost functions (Maciejowski, 2002).

Recently, some studies dedicated to DWN control are focussed on MPC to perform an optimal management of the DWN system and supply the consumer demand while preserving the DWN reliability, e.g. by tuning the weights of the optimization problem according to a wear index (Grosso Pérez et al., 2012), according to reliability importance measures (Salazar et al., to appear), or by imposing constraints concerning actuator reliability (Robles et al., 2016).

^{*} This work was supported by Spanish Government (MINISTERIO DE ECONOMÍA Y COMPETITIVIDAD) and FEDER under project DPI2014-58104-R (HARCRICS).

The reliability assessment and the reliability importance measures are presented in Section 2. The HAC scheme based on an MPC algorithm and the reliability integration into the control algorithm are presented in Section 3. Section 4 presents the DWN system and its reliability analysis. Finally, some conclusions are given in Section 5.

2. RELIABILITY ASSESSMENT

2.1 Components and system reliabilities

Reliability is defined as the probability that units, components, equipment, and systems will perform its functioning satisfactorily for a specified period of time under some operating conditions and specific environments (Gertsbakh, 2001).

The reliability of the i th component of the system can be modeled using the exponential function as:

$$R_i(t) = e^{-\int_0^t \lambda_i(v)dv} \quad \forall i = 1, \dots, m \quad (1)$$

where $\lambda_i(t)$ is the failure rate, which can be explained by the classical failure rate bathtub curve evolution (Fig. 1). In the “burn-in” period the failure rate is high due mainly to design or manufacturing defects that can not be completely eliminated. In the “useful life” period the failure rate is considered almost constant, and in the third period called “wear-out”, the failure rate becomes greater due to the aging and wear of the component.




Fig. 1. Classical bathtub curve.

In this work, the failure rate in the useful life period is not constant, it is considered as a function of the use made of the component and its aging, as it will be presented later.

Generally, the objective in reliability optimization is to achieve higher levels of reliability at the end of the mission time $R_i(t_f)$ (Fig. 2), which is the probability that component i is able to satisfy its function at the end of the mission t_f , denoted as:

$$R_i(t_f) = e^{-\int_0^{t_f} \lambda_i(v)dv} \quad \forall i = 1, \dots, m \quad (2)$$




Fig. 2. Reliability representation $R_i(t)$.

The overall system reliability can be computed by means of its structure function. The system structure function allows determining the system state based on the state of their components (Gertsbakh, 2001) and is determined by the structure of the system (it could be serial, parallel or a more complex structure i.e. bridge structure) following the pivotal decomposition method. Alternatively, system reliability can be modeled using a Dynamic Bayesian Network (DBN) (Salazar et al., 2015).

In this work, it is assumed that the overall system reliability is determined by the reliability of its actuators.

2.2 Failure rate

The failure rate of the actuator varies with time and the actuator usage. In here, the failure rate in the useful life period of the actuator varies according to the impact of the load (use) and its age. This load dependency has been modeled in several ways, in this paper the proportional hazard model (Cox, 1972) is used:

$$\lambda_i(t) = \lambda_i^0 \times g(\ell, \vartheta) \quad \forall i = 1, \dots, m \quad (3)$$

where λ_i^0 is the baseline failure rate (nominal failure rate) for the i th actuator and $g(\ell, \vartheta)$ represents the effect of stress on the actuator known as a covariate, where ℓ represents an image of the load applied and ϑ is an actuator parameter.

In previous works (Salazar et al., 2015) the covariate was modeled as the normalized instantaneous actuator usage. In this work a new approach considering a covariate as a function of the load and the age of the actuator is proposed:

$$g_i(u_i(t)) = 1 + \beta_i \int_0^t |u_i(v)|dv \quad \forall i = 1, \dots, m \quad (4)$$

where $g_i(u_i(t))$ is defined as the cumulated applied control effort of the i th actuator from the beginning of the mission until time instant t_f and β_i is a constant parameter.

Using (4) in (3) it yields,

$$\lambda_i(t) = \lambda_i^0 \left(1 + \beta_i \int_0^t |u_i(v)|dv \right) \quad \forall i = 1, \dots, m \quad (5)$$

this definition implies that actuators are under a constant reliability decay due to the baseline failure rate which is increased when the actuators are used.

2.3 Reliability interpretations

In this work, two reliability interpretations will be studied. On the one hand, consider the reliability of an actuator given by (1). Remark that $R_i(0) = 1$ and that at each time instant $t > 0$ the reliability decreases according to its failure rate (5). This reliability interpretation will be referred as the *instantaneous reliability of the actuator*.

On the other hand, consider that the reliability of an actuator is computed at a given time $\tau \in [0, t_f]$. Thus, (1) becomes:

$$R_i^\tau(t) = e^{-\int_\tau^t \lambda_i(v)dv} \quad \forall i = 1, \dots, m \quad (6)$$

This implies that $R_i^\tau(\tau) = 1$ at current time (Fig. 3) and it can be interpreted that an actuator remains fully

reliable as long as it is not affected by a fault. Moreover, its reliability at mission time t_f evaluated at current time τ is denoted as:

$$R_i^\tau(t_f) = e^{-\int_\tau^{t_f} \lambda_i^\tau(v) dv} \quad \forall i = 1, \dots, m \quad (7)$$

where $\lambda_i^\tau(t)$ is the failure profile of the i th actuator determined at time τ and $R_i^\tau(t_f)$ denotes the reliability at the end of the mission time t_f computed at time instant τ (Fig. 3). This approach was introduced in Chamseddine et al. (2014).




Fig. 3. Expected reliability of the actuator $R_i^t(t_f)$.

This second reliability interpretation will be called the *expected reliability of the actuator*. The actuator can be characterized at instant time τ by a constant failure rate in the time interval $[\tau, t_f]$. Hence, the expected reliability of the actuator becomes:

$$R_i^\tau(t_f) = e^{-\lambda_i(\tau) \times (t_f - \tau)} \quad \forall i = 1, \dots, m \quad (8)$$

Regarding system reliability, under the first interpretation it will be called the *instantaneous system reliability*, denoted as $R_S(t)$. Under the second interpretation it will be called the *expected system reliability*, denoted as $R_S^\tau(t_f)$.

2.4 Importance reliability measures

To measure and quantify the impact of actuator failures over the functioning of the system, several indicators concerning reliability importance have been proposed, each of them with a particular purpose (Kuo and Zhu, 2012).

In this work, the Birnbaum's importance measure I_B (Birnbaum, 1969) will be considered. This importance measure quantifies the maximum decrease of system reliability due to reliability changes of the i th actuator. It can be defined as:

$$I_{B_i}(t) = \frac{\partial R_S(t)}{\partial R_i(t)} = R_S(1_i, t) - R_S(0_i, t) \quad (9)$$

The notation $R_S(1_i, t)$ denotes the reliability of the system in which the i th actuator is replaced by a fully reliable one, while $R_S(0_i, t)$ denotes the reliability of the system in which the i th actuator has failed.

According to both reliability interpretations, two Birnbaum's measures are proposed. On the one hand, under the instantaneous reliability interpretation, the actuator Birnbaum's importance measure will be computed as in (9), whereas under the expected reliability interpretation the following Birnbaum's importance measure will be considered.

$$I_{B_i}^\tau(t_f) = \frac{\partial R_S^\tau(t_f)}{\partial R_i^\tau(t_f)} = R_S^\tau(1_i, t_f) - R_S^\tau(0_i, t_f), \quad (10)$$

which is the actuator Birnbaum's importance measure at mission time instant t_f computed at current time τ .

3. HEALTH-AWARE MPC

3.1 MPC formulation

Consider the following linear discrete-time model described in the state-space form of an over actuated system:

$$\begin{aligned} x(k+1) &= Ax(k) + Bu(k) + E\varepsilon(k) \\ y(k) &= Cx(k) \end{aligned} \quad (11)$$

where $x(k) \in \mathbb{R}^n$ is the state vector, $u(k) \in \mathbb{R}^p$ is the control input vector with $u(k) \geq 0 \quad \forall k$, $y(k) \in \mathbb{R}^q$ is the measured output vector, $\varepsilon(k) \in \mathbb{R}^m$ is the disturbance vector, $A \in \mathbb{R}^{n \times n}$ is the state matrix, $B \in \mathbb{R}^{q \times p}$ input matrix, $E \in \mathbb{R}^{n \times m}$ is the disturbance matrix, and $C \in \mathbb{R}^{q \times n}$ is the output matrix.

The MPC algorithm uses a model of the system to predict the future output of the system and compute the optimal control actions aimed at optimizing a given cost function over a prediction horizon H_p . This cost function is minimized subject to a set of physical and operational constraints over a control horizon $H_c \leq H_p$. Once the minimization is performed, a vector of control actions is obtained and just the first component is applied to the system. The procedure is repeated for the next time instant following a receding horizon strategy and taking into account feedback system measurements and future set-points.

In this work, the multiobjective optimization problem is formulated as follows:

$$\begin{aligned} \text{minimize} \quad & J(k) = \sum_{j=0}^{H_c-1} \sum_{i=1}^p \Delta \hat{u}_i(k+j|k)^2 \\ & \hat{u}(k+H_c-1|k), \\ & \Delta \hat{u}(k|k), \dots, \\ & \Delta \hat{u}(k+H_c-1|k) \\ & + \sum_{j=0}^{H_c-1} \sum_{i=1}^p \rho_i(k) \hat{u}_i(k+j|k)^2 \\ \text{subject to} \quad & \underline{u} \leq \hat{u}(k+j|k) \leq \bar{u} \quad j = 0, \dots, H_c-1 \\ & \underline{x} \leq \hat{x}(k+l|k) \leq \bar{x} \quad l = 1, \dots, H_p \end{aligned} \quad (12)$$

where $\rho_i(k)$ is a weight, \underline{u} and \bar{u} denote the minimum and maximum actuator bounds, and \underline{x} and \bar{x} denote the minimum and maximum state bounds. The notation $k+j|k$ allows a future time instant $k+j$ to be referred at current time instant k , and $\Delta \hat{u}_i(k) \triangleq \hat{u}_i(k) - \hat{u}_i(k-1)$.

The first term of the objective function aims at guaranteeing a smooth actuator operation whereas the second term penalizes actuator operation according to their use cost $\rho_i(k)$. In this work, the control law dependence on reliability will be achieved through ρ_i weights.

Although a linear model has been taken into account in this work, a nonlinear model could also be considered. In such case, the model should be either linearized around an equilibrium point or Nonlinear Model Predictive Control (Grüne and Pannek, 2011) could be applied.

The Health-Aware Control scheme used in this paper was proposed in Salazar et al. (to appear) and facilitates

the exploration of different redistribution policies without significant changes in the control algorithm.

3.2 Redistribution policy

One of the objectives is to extend the overall system reliability by performing the optimal control actions over the system given a redistribution policy which is achieved by tuning the weight ρ_i .

Three weights assignments for ρ_i are proposed in this paper under both reliability interpretations.

Under the instantaneous reliability interpretation, the first assignment focuses actuators reliability in discrete time:

$$\rho_i(k) = 1 - R_i(k) \quad (13)$$

The objective of this weight assignment is to preserve the individual reliability of each actuator as the optimization algorithm will further penalize those actuators with lower reliability (Salazar et al., 2015).

The second weight assignment focuses the overall system reliability using the Birnbaum importance measure in discrete time:

$$\rho_i(k) = I_{B_i}(k) \quad (14)$$

The objective is further penalizing those actuators with a greater impact of their reliability change on the system reliability (Salazar et al., 2015).

Similarly, under the expected reliability interpretation, the first weight assignment corresponds to:

$$\rho_i(k) = 1 - R_i^k(k_f), \quad (15)$$

and the second one to:

$$\rho_i(k) = I_{B_i}^k(k_f) \quad (16)$$

In the third weight assignment, which is common for both reliability interpretations, no reliability is taken into account, i.e., $\rho_i(k) = 1$.

In Salazar et al. (2015), weights were already assigned following the instantaneous reliability approach. The novelty of this work consists in assigning the weights under the expected reliability interpretation.

3.3 Reliability performance assessment

Different indexes are proposed to compare both reliability interpretations. Firstly, the cumulative control effort index (U_{cum}) which indicates the amount of energy spent controlling the system,

$$U_{cum} = T_s \sum_{k=0}^{T_{sim}/T_s} [u(k)^T u(k)]. \quad (17)$$

Next, the cumulative system reliability, which indicates the aggregated system reliability over the simulation time. Under the instantaneous reliability interpretation, it is denoted in discrete time as:

$$R_{Scum} = T_s \sum_{k=0}^{T_{sim}/T_s} R_s(k), \quad (18)$$

and under the expected reliability interpretation, it is denoted as:

$$R_{Scum}^{k_f} = T_s \sum_{k=0}^{T_{sim}/T_s} R_s^k(k_f) \quad (19)$$

4. DRINKING WATER NETWORK APPLICATION

4.1 System description

In this work, an application over a Drinking Water Network (DWN) is presented. A DWN is a system composed of sources (water supplies), sinks (water demand sectors), reservoirs, pipelines that link sources to sinks through pumps and valves. The network consists of 5 sources and 1 demand sector (Fig. 4).




Fig. 4. Drinking Water Network system example

It is assumed that the demand forecast (d_m) at the sink is known and that any single source can satisfy this required water demand (Fig. 5).




Fig. 5. Drinking water demand.

By applying mass balance at each tank, the following linear discrete-time model is obtained:

$$\begin{aligned} x(k+1) &= Ax(k) + Bu(k) + B_d d_m(k) \\ y(k) &= Cx(k) \end{aligned} \quad (20)$$

where $x(k) \in \mathbb{R}^n$ are tanks volume, $u(k) \in \mathbb{R}^p$ are the control inputs (pump commands), $y(k) \in \mathbb{R}^q$ are the measured tanks volume, $d_m(k) \in \mathbb{R}^m$ is the water demand, $A \in \mathbb{R}^{n \times n}$ is the state matrix, $B \in \mathbb{R}^{q \times p}$ input matrix, $B_d \in \mathbb{R}^{n \times m}$ is the disturbance matrix, and $C \in \mathbb{R}^{q \times n}$ is the output matrix.

The objective of the MPC scheme (12) is to maintain the pumps and tanks under their bounds and extend the reliability of the system.

The simulation parameters are presented in Table 1.

Table 1. Simulation parameters

Parameter	Value				
H_p [h]	24				
H_c [h]	8				
T_s [h]	1				
β_i	$10^{-2} \forall i \in [1, 10]$				
\bar{u}_i [m^3/s]	0.75	0.75	0.75	1.20	0.85
	1.60	1.70	0.85	1.70	1.60
\underline{u}_i [m^3/s]	$0 \forall i \in [1, 10]$				
λ_i^0 [$h^{-1} \times 10^{-4}$]	9.85	10.70	10.50	1.40	0.85
	0.80	11.70	0.60	0.74	0.78
\bar{x}_i [m^3]	65200	3100	14450	11745	
\underline{x}_i [m^3]	25000	2200	5200	3500	
$x_i(0)$ [m^3]	45100	2650	9825	7622	

4.2 Reliability analysis

The five ρ_i assignments proposed at Section 3.2 have been considered in the MPC control of the DWN. All cases will be assessed under both reliability interpretations.

Figure 6 shows the instantaneous system reliability evolution and Fig. 7 provides the expected system reliability at the end of the mission time t_f . In Table 2, the reliability performance indexes are shown.




Fig. 6. Instantaneous system reliability.




Fig. 7. Expected system reliability at mission time t_f .

Results show that the best reliability performance is attained when using a redistribution policy based on the

Birnbaum's importance measure, i.e., (14) and (16), with a small improvement when the instantaneous reliability interpretation is followed, i.e., (14). Focusing on actuator reliability (i.e., (13) and (14)) does not optimize system reliability. However, targeting system reliability leads to a greater actuator energy expense.

Table 2. Reliability performance indexes.

$\rho_i(k)$	$R_{S_{cum}} [\times 10^6]$	$R_{S_{cum}}^{k_f} [\times 10^6]$	$U_{cum} [\times 10^6]$
1	5.6131	5.5583	1.5370
$1 - R_i(k)$	5.4046	5.4054	1.9687
$1 - R_i^k(k_f)$	5.4525	5.4340	1.9002
$I_{B_i}(k)$	6.1006	6.1653	3.2158
$I_{B_i}^k(k_f)$	6.0915	6.1447	3.5040

In general, remark that both reliability interpretations are almost equivalent since both approaches provide similar results.

Figures 8 and 9 provide the pump control actions and the tank volumes for the best redistribution policy, corresponding to (14). Note that, the DWN is able to supply the required water demand maintaining pump control efforts and tank volumes within the specified bounds.




Fig. 8. Pump commands corresponding to $\rho_i(k) = I_{B_i}(k)$.

5. CONCLUSIONS

In this paper, two reliability interpretations have been presented and illustrated using a DWN system. Both




Fig. 9. Tank volumes corresponding to $\rho_i(k) = I_{Bi}(k)$.

approaches have been applied to a Health-Aware Control scheme based on an MPC algorithm with the objective of improving system reliability.

The results of the redistribution policy provide similar results in terms of reliability enhancement independently of the reliability interpretation. Thus, both interpretations are virtually equivalent.

Additionally, a better-suited modeling of the failure rate considering the aggregated usage of the actuators has been proposed.

Future research will focus on the study of the robustness of both reliability approaches, i.e. determine how robust or sensitive are these approaches respect to the parameters selection.

REFERENCES

- Bicking, F., Weber, P., and Theilliol, D. (2013). Reliability importance measures for fault tolerant control allocation. In *2013 Conference on Control and Fault-Tolerant Systems (SysTol)*, 104–109.
- Birnbaum, Z.W. (1969). On the importance of different components in a multicomponent system. In P.R. Krishnaiah (ed.), *Multivariate analysis*, volume II, 581–592. Academic Press.
- Chamseddine, A., Theilliol, D., Sadeghzadeh, I., Zhang, Y., and Weber, P. (2014). Optimal reliability design for over-actuated systems based on the MIT rule: Application to an octocopter helicopter testbed. *Reliability Engineering & System Safety*, 132.
- Cox, D.R. (1972). Regression Models and Life-Tables. *Journal of the Royal Statistical Society. Series B (Methodological)*, 34(2), 187–220.
- Gertsbakh, I.B. (2001). *Reliability theory: with applications to preventive maintenance*. Springer, Berlin ; New York, 2nd edition.
- Grosso Pérez, J.M., Ocampo-Martinez, C., and Puig, V. (2012). A service reliability model predictive control with dynamic safety stocks and actuators health monitoring for drinking water networks. In *2012 IEEE 51st Annual Conference on Decision and Control (CDC)*.
- Grüne, L. and Pannek, J. (2011). *Nonlinear Model Predictive Control*. Communications and Control Engineering. Springer London, London.
- Khelassi, A., Theilliol, D., Weber, P., and Ponsart, J.C. (2011). Fault-tolerant control design with respect to actuator health degradation: An LMI approach. In *IEEE International Conference on Control Applications (CCA)*, 983–988.
- Kuo, W. and Zhu, X. (2012). *Importance measures in reliability, risk, and optimization: principles and applications*. John Wiley & Sons, Ltd, Hoboken, N.J.
- Maciejowski, J.M. (2002). *Predictive control: with constraints*. Prentice Hall.
- Robles, D., Puig, V., Ocampo-Martinez, C., and Garza-Castañón, L.E. (2016). Reliable fault-tolerant model predictive control of drinking water transport networks. *Control Engineering Practice*, 55.
- Salazar, J.C., Nejari, F., Sarrate, R., Weber, P., and Theilliol, D. (2016). Reliability importance measures for a health-aware control of drinking water networks. In *3rd Conference on Control and Fault-Tolerant Systems, SysTol 2016*.
- Salazar, J.C., Weber, P., Nejari, F., Sarrate, R., and Theilliol, D. (to appear). System reliability aware model predictive control framework. *Reliability Engineering & System Safety*.
- Salazar, J.C., Weber, P., Nejari, F., Theilliol, D., and Sarrate, R. (2015). MPC Framework for System Reliability Optimization. In Z. Kowalczyk (ed.), *Advanced and Intelligent Computations in Diagnosis and Control*, number 386 in Advances in Intelligent Systems and Computing, 161–177. Springer International Publishing.
- Zhang, Y. and Jiang, J. (2008). Bibliographical review on reconfigurable fault-tolerant control systems. *Annual Reviews in Control*, 32(2).