Robust Fault Tolerant Control Framework using Uncertain Takagi-Sugeno Fuzzy Models

Damiano Rotondo, Fatiha Nejari and Vicenç Puig

Abstract

This chapter is concerned with the introduction of a fault tolerant control (FTC) framework using uncertain Takagi-Sugeno (FS) fuzzy models. Depending on how much information is available about the fault, the framework gives rise to passive FTC, active FTC without controller reconfiguration and active FTC with controller reconfiguration. The design is performed using a Linear Matrix Inequality (LMI)-based synthesis that directly takes into account the TS description of the system and its uncertainties. An example based on a mobile robot is used to show the application of this methodology.

I. INTRODUCTION

Fault Tolerant Control (FTC) has been consolidated as an important research topic in the control applications during last years [1]–[3]. The objective of an FTC system is to maintain desirable closed-loop performance, or with an acceptable degradation, and preserve stability conditions in the presence of component and/or instrument faults. Accommodation capability of a control system depends on many factors such as severity of fault, robustness of the nominal system and mechanisms that introduce redundancy in sensors and/or actuators. Generally speaking, FTC systems can be categorized into two main groups: active and passive. The passive FTC techniques [4] are control laws that take into account the fault appearance as a disturbance, with resulting conservative control system performance. On the other hand, the active FTC techniques involve adapting the control law by using the information given by the Fault Detection and Isolation (FDI) block [2]. With this information, some automatic controller adjustments are done after the fault trying to guarantee acceptable control objectives. The main advantage of active FTC is that it overcomes the conservativeness of the passive FTC, but the price to pay is that the overall system becomes more complicated and costly.

This work has been funded by the Spanish MINECO through the project CYCYT SHERECS (ref. DPI2011-26243), by the European Commission through contract i-Sense (ref. FP7-ICT-2009-6-270428) and by UPC through the grant FPI-UPC E-01104.

Damiano Rotondo, Fatiha Nejari and Vicenç Puig are with Advanced Control Systems Group (SAC), Universitat Politècnica de Catalunya (UPC), TR11, Rambla de Sant Nebridi, 10, 08222 Terrassa, Spain. e-mail: damiano(dot)rotondo(at)yahoo(dot)it

The Takagi-Sugeno (TS) framework has also been deeply studied in the automatic control literature [5], [6]. Introduced in [7], TS systems provide an effective way of representing non-linear systems with the aid of fuzzy sets, fuzzy rules and a set of local linear models. The overall model of the system is obtained by merging the local models through fuzzy membership functions.

In recent years, the interest in TS systems for FTC has grown due to the possibility of using such a methodology to deal with non-linear systems [8]. The TS theory is mainly used for designing controllers for non-faulty systems, but recently it has also been used for active FTC (e.g. [9]–[11]).

This chapter introduces the idea of the robust TS framework, that is obtained as a combination of known results from the robust control area and the traditional TS control area. This framework can be used for fault tolerant control, with the advantage that, depending on how much information about the fault is available, the proposed framework can give rise to different FTC strategies: passive FTC, active FTC without controller reconfiguration and active FTC with controller reconfiguration. Finally, the proposed framework is illustrated with a mobile robot application.

The chapter is organized as follows. Section II presents the robust TS framework. Section III shows how such a framework can be used to obtain different types of FTC strategies. Section IV describes the application example. Section V presents the results. Finally, the main conclusions and the possible future work are summarized in Section VI.

II. THE ROBUST TS FRAMEWORK

A. TS Systems

TS systems, as proposed by Takagi and Sugeno [7], are described by local models merged together using fuzzy IF-THEN rules [5], as follows:

$$\begin{aligned} & \text{IF } \vartheta_1(\tau) \text{ is } M_{i1} \text{ AND } \dots \text{ AND } \vartheta_p(\tau) \text{ is } M_{ip} \\ & \text{THEN } \sigma.x(\tau) = A_i x(\tau) + B_i u(\tau) \quad i = 1, \dots, N \end{aligned} \quad (1)$$

where $\vartheta_1(\tau), \dots, \vartheta_p(\tau)$ are premise variables that can be functions of the state variables, external disturbances and/or time. Each linear consequent equation represented by $A_i x(\tau) + B_i u(\tau)$ is called a *subsystem*.

Given a pair $(x(\tau), u(\tau))$, the state of the TS system can easily be inferred:

$$\sigma.x(\tau) = \frac{\sum_{i=1}^N w_i(\vartheta(\tau)) (A_i x(\tau) + B_i u(\tau))}{\sum_{i=1}^N w_i(\vartheta(\tau))} = \sum_{i=1}^N \rho_i(\vartheta(\tau)) (A_i x(\tau) + B_i u(\tau)) \quad (2)$$

where $\vartheta(\tau) = [\vartheta_1(\tau), \dots, \vartheta_p(\tau)]$ is the vector containing the premise variables, and $w_i(\vartheta(\tau))$ and $\rho_i(\vartheta(\tau))$ are defined as

follows:

$$w_i(\vartheta(\tau)) = \prod_{j=1}^p M_{ij}(\vartheta_j(\tau)) \quad (3)$$

$$\rho_i(\vartheta(\tau)) = \frac{w_i(\vartheta(\tau))}{\sum_{i=1}^N w_i(\vartheta(\tau))} \quad (4)$$

where $M_{ij}(\vartheta_j(\tau))$ is the grade of membership of $\vartheta_j(\tau)$ in M_{ij} and $\rho_i(\vartheta(\tau))$ is such that:

$$\begin{cases} \sum_{i=1}^N \rho_i(\vartheta(\tau)) = 1 \\ \rho_i(\vartheta(\tau)) \geq 0, \quad i = 1, \dots, N \end{cases} \quad (5)$$

B. The Robust TS Controller

In this chapter, a Robust TS framework that is based on the combination of robust polytopic and Takagi-Sugeno design is proposed. In this framework, the variation of the state matrix is due to the vector of premise parameter ϑ , whose measurement or estimation is supposed to be available, and some bounded uncertainties. The nominal TS model is used to generate a polytope described by its vertices (e.g. $A_1, A_2, \dots, A_5$ in Fig.1). Later, the model uncertainties are taken into account generating more polytopes, one for each vertex of the nominal polytope (e.g. $A_{1,1}, A_{1,2}, A_{1,3}, A_{1,4}$ around the first nominal vertex A_1). The Robust TS design problem is to obtain a controller inferred by ϑ as a combination of vertex controllers ($K_1, K_2, \dots, K_5$). Each vertex controller is designed so as to satisfy some LMI conditions at all the vertices of the vertex polytope. Under some assumptions, the final result will be a TS controller inferred by ϑ that is robust against bounded uncertainties.

Fig. 1. Uncertain Takagi-Sugeno System.

C. Design Using LMI-based Pole Placement

Consider the TS system (1) and assume that each subsystem is described by uncertain state-space matrices as follows:

$$A_i = A_{Ni} + \Delta A_i \quad (6)$$

$$B_i = B_{Ni} + \Delta_{B_i} \quad (7)$$

where A_{Ni} and B_{Ni} denote the nominal matrices while Δ_{A_i} and Δ_{B_i} denote the respective uncertain part, for the i -th subsystem, that are described in a polytopic way as follows:

$$\Delta_{A_i} = \sum_{j=1}^M \eta_{ij} \Delta_{A_{ij}} \quad (8)$$

$$\Delta_{B_i} = \sum_{j=1}^M \eta_{ij} \Delta_{B_{ij}} \quad (9)$$

with $\sum_{j=1}^M \eta_{ij} = 1$ and $\eta_{ij} > 0$. Hence, following (2), the state of the TS system is inferred as:

$$\sigma.x(\tau) = \sum_{i=1}^N \rho_i(\vartheta(\tau)) ((A_{Ni} + \Delta_{A_i})x(\tau) + (B_{Ni} + \Delta_{B_i})u(\tau)) \quad (10)$$

with $\rho_i(\vartheta(\tau))$ defined as in (4).

Given an LMI region $\mathcal{D} = \{z \in \mathbb{C} : f_{\mathcal{D}}(z) < 0\}$ with characteristic function [14]:

$$f_{\mathcal{D}}(z) = \alpha + z\beta + \bar{z}\beta^T = [\alpha_{kl} + \beta_{kl}z + \beta_{lk}\bar{z}]_{1 \leq k, l \leq m}$$

where $\alpha = [\alpha_{kl}] \in \mathbb{R}^{m \times m}$ and $\beta = [\beta_{kl}] \in \mathbb{R}^{m \times m}$ are symmetric matrices, the problem to be solved consists of finding a Takagi-Sugeno state-feedback controller, as follows:

$$\begin{aligned} & \text{IF } \vartheta_1(\tau) \text{ is } M_{i1} \text{ AND } \dots \text{ AND } \vartheta_p(\tau) \text{ is } M_{ip} \\ & \text{THEN } u(\tau) = K_i x(\tau) \end{aligned} \quad (11)$$

that is, to calculate the gains K_i such that the closed-loop poles of (2) are robustly placed in $\mathcal{D}$, independently of the values taken by the uncertain matrices Δ_{A_i} and Δ_{B_i} . The main motivation for seeking pole clustering in specific regions of the complex plane is that, by constraining the eigenvalues to lie in a prescribed region, stability can be guaranteed and a satisfactory transient response can be ensured. The following theorem is valid:

Theorem 1: Let $\mathcal{D}$ be an LMI region and assume that, for each uncertain LTI subsystem in (1) described by the matrix pair (A_i, B_i) as in (6)-(9), a state-feedback gain K_i and a Lyapunov matrix $X = X^T > 0$ have been obtained such that:

$$\left[\alpha_{kl}X + \beta_{kl}((A_{Ni} + \Delta_{A_{ij}})X + (B_{Ni} + \Delta_{B_{ij}})\Gamma_i) + \beta_{lk}((A_{Ni} + \Delta_{A_{ij}})X + (B_{Ni} + \Delta_{B_{ij}})\Gamma_i)^T \right]_{1 \leq k, l \leq m} < 0 \quad (12)$$

for each $t = 1, \dots, N$ and $j = 1, \dots, M$, where $\Gamma_i = K_i X$.

Moreover, assume that a single Lyapunov matrix X has been used to solve this problem for all the subsystems. Then, the TS state-feedback controller (11) places the closed-loop poles of (1) in $\mathcal{D}$, independently of the values taken by the uncertain matrices Δ_{A_i} and Δ_{B_i} .

Proof: Due to a basic property of matrices [12], any linear combination of (12) with non-negative coefficients is negative definite. Hence, using the linear combination given by (8)-(9) leads to:

$$\sum_{j=1}^M \eta_{ij} \left[\alpha_{kl} X + \beta_{kl} ((A_{Ni} + \Delta_{A_{ij}}) X + (B_{Ni} + \Delta_{B_{ij}}) \Gamma_i) + \beta_{lk} ((A_{Ni} + \Delta_{A_{ij}}) X + (B_{Ni} + \Delta_{B_{ij}}) \Gamma_i)^T \right]_{1 \leq k, l \leq m} \leq 0 \quad (13)$$

that can be rewritten, taking into account that $\sum_{j=1}^M \eta_{ij} = 1$, and through simple mathematical manipulation, in the following form:

$$\left[\alpha_{kl} X + \beta_{kl} ((A_{Ni} + \Delta_{A_i}) X + (B_{Ni} + \Delta_{B_i}) \Gamma_i) + \beta_{lk} ((A_{Ni} + \Delta_{A_i}) X + (B_{Ni} + \Delta_{B_i}) \Gamma_i)^T \right]_{1 \leq k, l \leq m} \leq 0 \quad (14)$$

Then, considering twice the linear combination given by the coefficients $\rho_i(\vartheta(\tau))$ in (4), the following can be written:

$$\sum_{i=1}^N \rho_i(\vartheta(\tau)) \sum_{t=1}^N \rho_t(\vartheta(\tau)) \left[\alpha_{kl} X + \beta_{kl} ((A_{Ni} + \Delta_{A_i}) X + (B_{Ni} + \Delta_{B_i}) \Gamma_i) + \beta_{lk} ((A_{Ni} + \Delta_{A_i}) X + (B_{Ni} + \Delta_{B_i}) \Gamma_i)^T \right]_{1 \leq k, l \leq m} \leq 0 \quad (15)$$

that is a necessary and sufficient condition for $\mathcal{D}$ -stability of parallel distributed controllers [13], obtained as an extension of [14].

III. FAULT TOLERANT CONTROL

A. System and fault modelling

Let us consider the faulty uncertain system represented by the following T-S model:

$$\begin{aligned} & \text{IF } \vartheta_1(\tau) \text{ is } M_{i1} \text{ AND } \dots \text{ AND } \vartheta_p(\tau) \text{ is } M_{ip} \\ & \text{THEN } \sigma.x_f(\tau) = (A_{Ni} + \Delta_{A_i})x_f(\tau) + (B_{Ni} + \Delta_{B_i})u_f(\tau) \quad i = 1, \dots, N \end{aligned} \quad (16)$$

Given a pair $(x_f(\tau), u_f(\tau))$, the faulty state of the TS system can easily be inferred:

$$\sigma.x_f(\tau) = \sum_{i=1}^N \rho_i(\vartheta(\tau)) ((A_{Ni} + \Delta_{A_i})x_f(\tau) + (B_{Ni} + \Delta_{B_i})u_f(\tau)) \quad (17)$$

where N is the number of subsystems, $x_f(\tau) \in \mathbb{R}^{n_x}$ is the faulty state vector, $u_f(\tau) \in \mathbb{R}^{n_u}$ is the faulty control input vector. $A_{Ni} \in \mathbb{R}^{n_x \times n_x}$, $B_{Ni} \in \mathbb{R}^{n_u \times n_x}$ are the i -th nominal state matrix and the i -th nominal input matrix, respectively. Δ_{A_i} and Δ_{B_i} represent time varying parametric uncertainties with appropriate dimensions corresponding to the i -th subsystem.

The premise variables $\vartheta(\tau)$ are typically associated to changes in the operating conditions and it is assumed that their values can be measured, computed, or estimated in real-time using the available measurements. On the other hand, the time-varying parameters Δ_{A_i} and Δ_{B_i} associated to model uncertainties, are unknown, and cannot be used to infer accordingly the controller, even though some knowledge *a priori* available can be exploited in the controller design phase.

The parametric faults f (multiplicative) are assumed to belong to a set of faults $\mathfrak{F}$ that can be expressed as:

$$\mathfrak{F} = \{f_1, f_2, \dots, f_N\} = [F_1] \times [F_2] \times \dots \times [F_N]$$

where $[F_i] = [F_i, \overline{F_i}]$, $\forall i = 1, \dots, N$.

The Robust TS Framework presented in Section II can be used to deal with faults. More precisely, depending on how much information is available about the fault and the type of FTC technique to be used, the proposed control framework gives rise to different FTC strategies. An advantage of the proposed robust TS framework is that it allows to represent a wide spectrum of fault types for example actuators and process faults, affecting the matrices B and A , respectively. Moreover, different fault dynamics (abrupt or incipient) can be represented through the time variance of the parameters. Another advantage of the proposed framework is that, in contrast with other FTC design methodologies that only allow to take into account finite sets of faulty behaviors (for instance, a finite set of constant pairs (A_f, B_f)), the proposed framework allows to specify intervals of fault magnitudes, that is an infinite set of faulty behaviors the FTC system has to deal with.

B. Passive FTC

In the passive FTC approach, it is assumed that no information about the faults is available. Hence, tolerance against faults can only be achieved by considering faults as if they were uncertainties. A single controller is designed in such a way that it exhibits some robustness properties. More specifically, the faults $f \in \mathfrak{F}$ are considered to be unknown parameters and a single set of subsystem controllers K_i is designed so as to be inferred by the premise variables $\vartheta(\tau)$ and to be robust against model uncertainties Δ_{A_i} and Δ_{B_i} and faults. This strategy has the advantage of not needing a fault detection, isolation and estimation (FDIE) algorithm but, on the other hand, the controller has the highest possible conservativeness.

C. Active FTC without controller reconfiguration

The conservativeness of the passive approach can be overcome by considering that some information available about the fault can be used to infer accordingly the controller. More specifically, the faults $f \in \mathfrak{F}$ are considered to be varying parameters whose value is known or can be estimated through the information coming from a Fault Estimation (FE) module. This information can be used to infer accordingly between a single set of subsystem controllers K_i that are designed to be robust against model uncertainties. In this case the controller is not reconfigured, as it is the same as the one designed in the nominal case.

D. Active FTC with controller reconfiguration and fault detection (FD)

In this case, the faults $f \in \mathfrak{F}$ are considered to be uncertain parameters, but a fault detection (FD) algorithm that can detect the fault occurrence at time-instant T_D is introduced. Two set of subsystem controllers are designed:

- $K_{i_0}(\tau)$, designed to be robust against model uncertainties;

- $K_{i_D}(\tau)$, designed to be robust against model uncertainties and faults;

The switching between the two sets of subsystem controllers is done according to the following law:

$$K_i = \begin{cases} K_{i_0}(\tau) & \text{for } \tau < T_D \\ K_{i_D}(\tau) & \text{for } \tau \geq T_D \end{cases}$$

The advantage of this approach is less conservativeness in the nominal non-faulty case.

E. Active FTC with controller reconfiguration and fault detection and isolation (FDI)

In this case, the faults $f \in \mathfrak{F}$ are considered to be uncertain parameters, and a fault detection and isolation (FDI) algorithm can detect the fault occurrence at time-instant T_D and isolate the fault in the set $\mathfrak{F}$ at time-instant T_I . Then, $N+2$ sets of subsystem controllers are designed:

- $K_{i_0}(\tau)$, designed to be robust against model uncertainties ;
- $K_{i_D}(\tau)$, designed to be robust against model uncertainties and all the possible faults in $\mathfrak{F}$;
- N controllers $K_{i_l}^1(\tau), \dots, K_{i_l}^N(\tau)$, where the i^{th} controller $K_{i_l}^j(\tau)$ is designed to be robust against model uncertainties and the j^{th} fault F_j .

The switching between the sets of subsystem controllers is done according to the following law:

$$K_i = \begin{cases} K_{i_0}(\tau) & \text{for } \tau < T_D \\ K_{i_D}(\tau) & \text{for } T_D \leq \tau < T_I \\ K_{i_l}^j(\tau) & \text{for } \tau \geq T_I \end{cases}$$

F. Active FTC with controller reconfiguration and fault detection, isolation and estimation (FDIE)

In this case, an estimation of the faults $f \in \mathfrak{F}$ is provided by a fault estimation algorithm, and such an estimation can be used as a premise variable for the controller. Moreover, it is assumed that the FDI algorithm can detect the fault occurrence at time-instant T_D and isolate the fault in the set $\mathfrak{F}$ at time-instant T_I . Then, $N+2$ sets of subsystem controllers are designed:

- $K_{i_0}(\tau)$, inferred by the premise variables $\vartheta(\tau)$ and designed to be robust against model uncertainties;
- $K_{i_D}(\tau)$, inferred by the premise variables $\vartheta(\tau)$ and designed to be robust against model uncertainties and all the possible faults in $\mathfrak{F}$, considered as if they were uncertain parameters;
- N sets of subsystem controllers $K_{i_l}^1(F_1(\tau)), \dots, K_{i_l}^N(F_N(\tau))$, where the j^{th} controller $K_{i_l}^j(F_j(\tau))$ is inferred by the premise variables and the j^{th} fault estimation, used as an additional premise variable $F_i(\tau)$, and is designed to be robust against model uncertainties.

The switching between the different sets of subsystem controllers is done according to the following law:

$$K_i = \begin{cases} K_{i_0}(\tau) & \text{for } \tau < T_D \\ K_{i_D}(\tau) & \text{for } T_D \leq \tau < T_I \\ K_{i_I}^j(F_j(\tau)) & \text{for } \tau \geq T_I \end{cases}$$

IV. APPLICATION EXAMPLE

The application example used in this chapter is a two-wheel differential robot in simulation. The robot has a circular shape with a diameter $d = 2r = 0.34m$ and a mass $m = 2.92kg$. The vehicle is driven by two differential drive wheels that can reach the maximum speed of $\dot{z}_{\max} = 0.5m/s$. By altering the speed of the individual wheels, the direction of the robot movements can be changed.

Fig. 2. The two-wheel differential robot example.

A mathematical model of the robot (Fig. 2) can be obtained through a balance of the forces and the moments acting on the system:

$$\begin{cases} m\ddot{z} = (F_L + F_R - F_{drag,L} - F_{drag,R}) \\ \frac{1}{2}mr^2\ddot{\theta} = (F_R - F_L + F_{drag,L} - F_{drag,R})r \end{cases} \quad (18)$$

where:

$$F_{drag,L} = k_{drag}v_L|v_L| \quad F_{drag,R} = k_{drag}v_R|v_R|$$

$$v_L = \dot{z} - r\dot{\theta} \quad v_R = \dot{z} + r\dot{\theta}$$

with $k_{drag} = 11kg/m$ being the drag coefficient in the normal operating conditions, z the total covered distance, $\dot{z}$ the linear velocity, θ the yaw angle and $\dot{\theta}$ the angular velocity. The system can be controlled using the available control input F_L and F_R , that are the forces acting on the left and the right wheel, respectively.

By considering the state vector $x = \begin{bmatrix} z & \dot{z} & \theta & \dot{\theta} \end{bmatrix}^T$, the input vector $u = \begin{bmatrix} F_L & F_R \end{bmatrix}^T$, and embedding the nonlinearities in the parameters, (18) can be put in the following form:

$$\begin{pmatrix} \dot{x}_1 \\ \dot{x}_2 \\ \dot{x}_3 \\ \dot{x}_4 \end{pmatrix} = \begin{pmatrix} 0 & 1 & 0 & 0 \\ 0 & a_{22}(x_2, x_4) & 0 & a_{24}(x_2, x_4) \\ 0 & 0 & 0 & 1 \\ 0 & a_{42}(x_2, x_4) & 0 & a_{44}(x_2, x_4) \end{pmatrix} \begin{pmatrix} x_1 \\ x_2 \\ x_3 \\ x_4 \end{pmatrix} + B \begin{pmatrix} u_1 \\ u_2 \end{pmatrix} \quad (19)$$

with:

$$B = \begin{pmatrix} 0 & 1/m & 0 & -2/(mr) \\ 0 & 1/m & 0 & 2/(mr) \end{pmatrix}^T$$

$$a_{22}(x_2, x_4) = \begin{cases} -2k_{drag}x_2/m & x_2 \geq |rx_4| \\ -2rk_{drag}x_4/m & -rx_4 < x_2 < rx_4 \\ 2rk_{drag}x_4/m & rx_4 < x_2 < -rx_4 \\ 2k_{drag}x_2/m & x_2 \leq |rx_4| \end{cases}$$

$$a_{24}(x_2, x_4) = \begin{cases} -2k_{drag}r^2x_4/m & x_2 \geq |rx_4| \\ -2rk_{drag}x_2/m & -rx_4 < x_2 < rx_4 \\ 2rk_{drag}x_2/m & rx_4 < x_2 < -rx_4 \\ 2k_{drag}r^2x_4/m & x_2 \leq |rx_4| \end{cases}$$

$$a_{42}(x_2, x_4) = \begin{cases} -4k_{drag}x_4/m & x_2 \geq |rx_4| \\ -4k_{drag}x_2/(mr) & -rx_4 < x_2 < rx_4 \\ 4k_{drag}x_2/(mr) & rx_4 < x_2 < -rx_4 \\ 4k_{drag}x_4/m & x_2 \leq |rx_4| \end{cases}$$

$$a_{44}(x_2, x_4) = \begin{cases} -4k_{drag}x_2/m & x_2 \geq |rx_4| \\ -4rk_{drag}x_4/m & -rx_4 < x_2 < rx_4 \\ 4rk_{drag}x_4/m & rx_4 < x_2 < -rx_4 \\ 4k_{drag}x_2/m & x_2 \leq |rx_4| \end{cases}$$

Using $a_{22}(x_2, x_4)$, $a_{24}(x_2, x_4)$, $a_{42}(x_2, x_4)$ and $a_{44}(x_2, x_4)$ as premise variables, the approach described in [5], [15], often referred to as *bounding box method* is used for obtaining a Takagi-Sugeno model described by 8 subsystems as follows:

IF $a_{22}(x_2, x_4)$ is M_{i22} AND $a_{24}(x_2, x_4)$ is M_{i24} AND $a_{44}(x_2, x_4)$ is M_{i44}

$$THEN \begin{pmatrix} \dot{x}_1(t) \\ \dot{x}_2(t) \\ \dot{x}_3(t) \\ \dot{x}_4(t) \end{pmatrix} = \begin{pmatrix} 0 & 1 & 0 & 0 \\ 0 & \tilde{a}_{22} & 0 & \tilde{a}_{24} \\ 0 & 0 & 0 & 1 \\ 0 & \frac{2\tilde{a}_{24}}{r^2} & 0 & \tilde{a}_{44} \end{pmatrix} \begin{pmatrix} x_1(t) \\ x_2(t) \\ x_3(t) \\ x_4(t) \end{pmatrix} + \begin{pmatrix} 0 & 0 \\ 1/m & 1/m \\ 0 & 0 \\ \frac{-2}{mr} & \frac{2}{mr} \end{pmatrix} \begin{pmatrix} u_1(t) \\ u_2(t) \end{pmatrix} \quad (20)$$

where $\tilde{a}_{jk}$ can either be a minimum value $\underline{a}_{jk}$ or a maximum value $\bar{a}_{jk}$, depending on the subsystem taken in consideration.

Accordingly, the membership functions M_{ijk} can have one of the following structures:

$$M_{1jk} = \frac{\bar{a}_{jk} - a_{jk}}{\bar{a}_{jk} - \underline{a}_{jk}} \quad or \quad M_{2jk} = \frac{a_{jk} - \underline{a}_{jk}}{\bar{a}_{jk} - \underline{a}_{jk}} \quad (21)$$

V. RESULTS

The two-wheel robot can be affected by parametric faults (unexpected change in the drag coefficient k_{drag}), and sensor/actuator faults. In Fig. 3, the time response of the robot with different values of the drag coefficient is compared under the following conditions:

- the controller is designed to put the closed-loop poles in a circle of center $(-5.5, 0)$ and radius 4.5 without taking into account the possibility of faults occurrence;
- the Takagi-Sugeno model (20) is obtained through the *bounding box method* using the following extreme values for the state variables affecting the premise variables:

$$x_2^{\min} = -0.5 \quad x_2^{\max} = 0.5 \quad x_4^{\min} = -3 \quad x_4^{\max} = 3$$

- the reference is chosen as follows:

$$\begin{bmatrix} x_2^{ref}(t) \\ x_4^{ref}(t) \end{bmatrix} = \begin{cases} [0.1, 0.2]^T & t \leq 15s \\ [0.4, 0.3]^T & 15s < t \leq 30s \\ [-0.3, -0.7]^T & 30s < t \leq 60s \end{cases}$$

$$x_1^{ref}(t) = \int_0^t x_2^{ref}(t) dt \quad x_3^{ref}(t) = \int_0^t x_4^{ref}(t) dt$$

It can be seen that the controller has an intrinsic robustness against faults and can tolerate them until a certain magnitude without loosing the system stability (e.g. $k_{drag}^f = 5 \text{ kg/m}$, corresponding to the red line). However, taking a look at the position of the poles under fault occurrence (Fig. 4), it can be seen that even though the fault $k_{drag}^f = 5 \text{ kg/m}$ does not affect the system stability, it compromises its performance, as the desired specification in terms of poles location is no longer respected.

Fig. 3. Time response of the robot under fault occurrence.

Fig. 4. Pole placement of the robot under fault occurrence without FTC for different possible values of the faulty drag coefficient.

Using passive FTC, it is possible to enforce the robustness of the controller under fault occurrence. Once a desired region of the complex plane has been chosen, it is possible to find a lower bound for the faulty drag coefficient that makes the design LMIs feasible. In this example, for the circle of center $(-5.5, 0)$ and radius 4.5, a limit value of $k_{drag}^f = 7 \text{ kg/m}$ has been found. Fig. 5 shows a comparison between the closed-loop poles without FTC and the ones with passive FTC with such a value of the faulty drag coefficient, for 10000 different realizations of the robot state matrix. It can be seen that if no fault tolerance is enforced during the design phase, the poles can escape from the desired region. The proposed approach avoids such undesired behavior.

On the other hand, active FTC is less conservative than passive FTC because the fault is dealt with as it were a scheduling variable and not an additional uncertainty against which robustness must be enforced. A lesser conservativeness can be seen analyzing the lower bound for the faulty drag coefficient that makes the design LMIs feasible for the desired region of

Fig. 5. Robot under fault occurrence: comparison between pole placement without FTC (left figure) and pole placement with passive FTC (right figure) with $K_{drag} = 7 \text{ kg/m}$.

the complex plane. In Fig. 6, it is shown that active FTC is able to satisfy the desired specifications for a circle of center $(-5.5, 0)$ and radius 4.5 for any value of the faulty drag coefficient until 0 kg/m . The position of the closed-loop poles does not depend on the specific realization of the state matrix.

Fig. 6. Pole placement of the robot under fault occurrence with active FTC for different possible values of the faulty drag coefficient.

However, a drawback of the active FTC methods is that the precision of the fault estimation can affect the performances in terms of fault tolerance. This is shown in Fig. 7, where it can be seen that as the uncertainty in the fault estimation, in this work modeled as random noise uniformly distributed around the real value of the faulty drag coefficient, grows, so does the variation of the closed-loop poles position. This effect may even cause the closed-loop poles to leave the desired region of the complex plane, as in the case of an estimation error bigger than 80% of the real value of the faulty drag coefficient.

Fig. 7. Pole placement of the robot under fault occurrence with active FTC for different possible uncertainties of the fault estimation ($k_{drag}^f = 5 \text{ kg/m}$).

The comparison between passive FTC and active FTC has been carried out for different regions of the complex plane, all expressed as circles with a certain center $(-q, 0)$ and a certain radius r . For a lack of space, the obtained results are not shown in a graphical form, but summarized in Table I, where the lower bound on the value of k_{drag}^f for which fault tolerance is guaranteed is given for each circle in both the passive and the active FTC cases. Moreover, for the active FTC case, the tolerated uncertainty is shown too. It can be seen that there is a trade-off between performances and tolerable fault in the passive FTC case, and between performance and tolerable uncertainty in the active FTC case. It appears clearly that the designer of the FTC system should choose the strategy according to the availability of an estimation of the fault magnitude and the goodness of this estimation.

VI. CONCLUSIONS AND FUTURE WORK

In this chapter, a robust Takagi-Sugeno framework has been proposed and applied to the problem of fault tolerant control. It has been shown that the proposed framework can lead to the design of: a passive FTC, where a single set of subsystem controllers exhibits some robustness properties; an active FTC without controller reconfiguration, where the available fault information is used to infer accordingly the controller; and an active FTC with controller reconfiguration. In this last case, different sets of controllers are used before fault detection, between fault detection and fault isolation, and after fault isolation, respectively.

TABLE I

COMPARISON BETWEEN PASSIVE FTC AND ACTIVE FTC

Center	Radius	k_{drag}^f pas.	k_{drag}^f act.	Tol. unc. ($k_{drag}^f = 5 \text{ kg/m}$)
(-10.5,0)	10.5	0 kg/m	0 kg/m	210%
(-9.5,0)	9.5	0.5 kg/m	0 kg/m	190%
(-8.5,0)	8.5	1.6 kg/m	0 kg/m	160%
(-7.5,0)	7.5	2.6 kg/m	0 kg/m	150%
(-6.5,0)	6.5	3.8 kg/m	0 kg/m	130%
(-5.5,0)	5.5	5.9 kg/m	0 kg/m	100%
(-5.5,0)	4.5	7 kg/m	0 kg/m	80%
(-5.5,0)	3.5	8.6 kg/m	0 kg/m	20%
(-5.5,0)	2.5	9.9 kg/m	0 kg/m	10%
(-5.5,0)	1.5	10.6 kg/m	0 kg/m	6%
(-5.5,0)	0.5	11 kg/m	0 kg/m	0.6%

Results have been obtained designing passive and active FTC for a two-wheel differential robot simulator subject to a parametric fault, namely a change in the drag coefficient with respect to the normal operating conditions. The obtained controllers have been compared in terms of pole placement specifications. Such comparison has shown that the passive FTC conservativeness results in a bigger lower bound of the faulty drag coefficient for which fault tolerance can be achieved, with respect to the active FTC. On the other hand, the latter is sensitive to uncertainties in the fault estimation that can reduce, or even eliminate, the benefits of such approach.

REFERENCES

- [1] R. J. Patton, "Fault-Tolerant Control Systems: The 1997 situation," *Proceedings of the IFAC Symposium: SAFEPROCESS'97, Hull, UK.*, vol. 2, pp. 1033–1055, 1997.
- [2] M. Blanke, M. Kinnaert, J. Lunze, and M. Staroswiecki, *Diagnosis and Fault-Tolerant Control*. Springer-Verlag Berlin Heidelberg, 2003.
- [3] Y. Zhang and J. Jiang, "Bibliographical review on reconfigurable fault-tolerant control systems," *Annual Reviews in Control*, vol. 32, no. 2, pp. 229–252, 2008.
- [4] J. Chen, R. J. Patton, and Z. Chen, "An LMI Approach to Fault-Tolerant Control of Uncertain Systems," in *IEEE Conference on Decision and Control*, vol. 1, 1998, pp. 175–180.
- [5] K. Tanaka and H. O. Wang, *Fuzzy control systems design and analysis: A linear matrix inequality approach*. John Wiley and Sons, Inc., 2001.
- [6] J. Kluska, *Analytical methods in fuzzy modeling and control*. Springer-Verlag, Berlin, Heidelberg, 2009.
- [7] T. Takagi and M. Sugeno, "Fuzzy Identification of Systems and Its Applications to Modeling and Control," *IEEE Transactions on Systems, Man, and Cybernetics*, vol. SMC-15, no. 1, pp. 116–132, 1985.
- [8] C. J. Lopez-Toribio and R. J. Patton, "Takagi-Sugeno Fuzzy Fault-Tolerant Control for a Non-linear System," *Proceedings of the 38th IEEE Conference on Decision and Control*, vol. 5, pp. 4368–4373, 1999.

- [9] Ł. Dziekan and M. Witczak and J. Korbicz, "Active fault-tolerant control design for Takagi-Sugeno fuzzy systems," *Bulletin of the Polish Academy of Sciences, Technical Sciences*, vol. 59, no. 1, pp. 93–102, 2011.
- [10] J. Diao and K. M. Passino, "Stable fault-tolerant adaptive fuzzy/neural control for a turbine engine," *IEEE Transactions on Control Systems Technology*, vol. 9, no. 3, pp. 494–509, 2001.
- [11] A. Ichtev, J. Hellendoorn, R. Babuska, and S. Molloy, "Fault-tolerant model-based predictive control using multiple takagi-sugeno fuzzy models," in *Proceedings of the IEEE International Conference on Fuzzy Systems*, vol. 1, 2002, pp. 346–351.
- [12] R. A. Horn and C. R. Johnson, *Matrix Analysis*. Cambridge University Press, 1990.
- [13] L. He and G.-R. Duan, "Robust H_∞ control with pole placement constraints of T-S fuzzy systems," *Advances in Machine Learning and Cybernetics - Lecture Notes in Computer Science*, vol. 3930, pp. 338–346, 2006+.
- [14] M. Chilali and P. Gahinet, " H_∞ Design with Pole Placement Constraints: An LMI Approach," *IEEE Transactions on Automatic Control*, vol. 41, no. 3, pp. 358–367, 1996.
- [15] X. D. Sun and I. Postlethwaite, "Affine LPV modeling and its use in Gain-Scheduled Helicopter Control," in *UKACC International Conference on Control*, 1998, pp. 1504–1509.