
## Sectors/Distribution

The building is divided into six different sectors. Each one has its own treatment system. In the towers it is based in the top area and in the nave sectors it is placed over the navetower connection bridge. Through this system, jeopardizing the environmental conditions of the public space underneath the building is avoided.

Each treatment unit has a heat pump along with a boiler that thermically acclimatizes the air in a treatment station, where its quality is controlled too. From here it is driven into the acclimatized rooms through an air conduction system. Inside the towers it is distributed vertically in the north block, and in the nave the conductions are placed in the north facade porticos.

In some cases, the return air is driven through the nontreated spaces, making the most of this air which still retains quality, to acclimatize indirectly. To guarantee quality air in the toilet facilities, a forced ventilation system is installed as stipulated by regulation.



## **BOX** in BOX Total volume 262.534m<sup>3</sup> active


The extraordinary dimensions of the built volume make the total treatment of the air non-viable, speaking in both eco-nomic and energetic terms. A strategy with two methods of acclimatizing which provide a partial treatment is followed, reducing costs and environmental impact.

34 %

The original building is understood as a large neutral container, inside which different buildings of autonomous functioning are introduced. The building envelope of the original nave is a surface that regulates the air exchange with the exterior, achieving through this the contribution of natural ventilation to acclimatizing the interior space.

V V V

+3,20



## Winter


La concepción de la totalidad del envolvente del edificio (cubierta y fachadas) como un elemento de captación de energía del exterior y la consideración del espacio interior como una masa acumulador de inercia térmica. En la turbine gallery controlando los movimientos del aire y ayudándose de un sistema puntual se logra una franja de 4 metros con unos niveles de confort aceptables. Los retornos de las cajas tratadas se pueden efectuar a través de la sala de turbinas.

# Comfort

The building contains two climatic areas. In one of them, the confort is actively obtained using technified systems along with some energy consumption. These make up the 34% of the total air volume.

The different volumes are treated separately, allowing a reduction in energetic cost, as the spaces are only treated when used, adjusting the peak use in each closed area in-dependently. They are understood as boxes inserted inside the structure so no energy is wasted on heating up the thick concrete elements. The volumes of air renovation are calculated to adjust the air distribution in the most efficient way.

For the remaining spaces, the confort levels are passively achieved. Through systems of solar protection and collection, winds, inertia... accepting that during some winter periods the levels will be lower than the standard, but creating a spatial continuity that would be impossible with the air conditioning seal.





### Summer


Principalmente el uso de la refrigeración nocturna para disipar el calor acumulado durante el día. La protec-ción solar mediante todo tipo de lamelas. La diferencia de temperatura entre la fachada norte con las sombras de las torres y la soleada fachada sur este asegura un tiro natural transversal. Contribuye la excavación bajo rasante de la planta sótano, ampliando el gradiente de temperatura entre la arte subterránea y la parte alta de la nave. La ventilación cruzada de la bolsa de aire caliente acumulada en la cubierta.


### Air circulation volumes per unit


Top tower gallery:  $9.500 \text{m}^3 \times 8 \text{v/h} = 76.000 \text{ m}^3 / \text{h}$ Viewpoint: 9.500 m<sup>3</sup> x 8v/h = 76.000 m<sup>3</sup>/h Restaurant: 9.500 m<sup>3</sup> x 8v/h = 76.000 m<sup>3</sup>/h Dwellings:  $2.050 \text{ m}^3 \times 6\text{v/h} = 12.300 \text{ m}^3/\text{h}$ Artists facilities: 53.166 m<sup>3</sup> x 6v/h = 318.996 m<sup>3</sup>/h Ateliers: 29.400 m3 x 6v/h = 176.400 m3/h Auditorium: 4.050 m³ x 10v/h = 40.500 m³/h Theater: 9.000 m<sup>3</sup> x 10v/h = 90.000 m<sup>3</sup>/h Exhibition boxes: 2.000 m<sup>3</sup> x 8v/h = 16.000 m<sup>3</sup>/h Labs:  $800 \text{ m}^3 \times 6\text{v/h} = 4.800 \text{ m}^3/\text{h}$ Administration:  $800 \text{ m}^3 \times 6\text{v/h} = 4.800 \text{ m}^3/\text{h}$ Shop:  $600 \text{ m}^3 \times 8v/h = 4.800 \text{ m}^3/h$ Bar: 4 500 m<sup>3</sup> x 10v/h = 45 000 m<sup>3</sup>/h Restoration:  $600 \text{ m}^3 \times 6\text{v/h} = 36.000 \text{ m}^3/\text{h}$ 











fl + 7.15

E: 1|500

Vertical shaft turbine hall Vertical shaft towers Vertical shaft towers stand by B Heating pump Air conditioning unit

Duct forced air

Duct treated air Duct return

Duct in floor treated air

Duct in floor return

Forced air extraction

Vertical conduction treated air

 Vertical conduction treated air Vertical conduction return

Legend

Floorplans E: 1|1.000

