


Pre-design sheet for an exergy optimised building design IEA ECBCS Annex 37 Steady state calculations for heating case Version 2.3							
Object: CASA ARIAS, RONCAL (NAVARRA)							
1. Project data, boundary conditions							
1							
2	Volume (inside) [m³]	V =	600				
3	Net floor area [m²]	A _N =	90				
4	Indoor air temperature [°C]	θ _i =	20				
5	Exterior air temperature [°C]	θ _e =	10	= θ _{ref} Reference temperature			
2. Heat losses							
2.1 Transmission losses Φ_T [W]							
8	Building part	Symbols	Area A _i [m²]	Thermal transmittance U _i [W/(m²K)]	U _i * A _i [W/K]	Temperature- correction- factor F _{xi} [-]	U _i * A _i * F _{xi} [W/K]
9	Exterior wall	EW 1	85,00	0,17	14,45	1	14,45
10		EW 2	85,00	0,17	14,45	1	14,45
11		EW 3	40,00	0,17	6,80	1	6,80
12		EW 4	40,00	0,17	6,80	1	6,80
13	Window	W 1	9,90	1,04	10,30	1	10,30
14		W 2	9,90	1,04	10,30	1	10,30
15		W 3	19,80	1,04	20,59	1	20,59
16		W 4	13,20	1,04	13,73	1	13,73
17	Door	D 1	2,00	0,90	1,80	1	1,80
18	Roof	R 1	100,00	0,23	23,00	1	23,00
19		R 2				1	
20		R 3				1	
21	Upper story floor	R 4				0,8	
22		R 5				0,8	
23	Wall to roof rooms	RW 1				0,8	
24		RW 2				0,8	
25	Walls and floors to unheated rooms	uhW 1				0,5	
26		uhW 2				0,5	
27	Floors to ground. Areas of unheated cellar to ground	G 1	90,00	0,20	18,00	0,6	10,80
28		G 2				0,6	
29		G 3				0,6	
30		G 4				0,6	
31		G 5				0,6	
32	Σ A _i = A =		494,80	Specific transmission heat loss Σ U _i * A _i * F _{xi} =		133,01	
33	Transmission heat losses [W]		Φ _T = Σ (U _i * A _i * F _{xi}) * (θ _i - θ _e) Φ _T = 133,01 * 10,00				Φ _T = 1.330,12
2.2 Ventilation heat losses Φ_V [W]							
35	Air exchange rate [ach/h]	n _d =	0,4				
36	Heat exchanger efficiency [-]	η _V =	83%				
37	Ventilation heat losses [W]		Φ _V = (cp * ρ * V * n _d * (1 - η _V)) * (θ _i - θ _e) Φ _V = 13,67 * 10,00				Φ _V = 136,68
3. Heat gains							
3.1 Solar heat gains Φ_s [W]							
40	Window frame fraction [-]	F _f =	0,71				
41	Orientation	Solar radiation I _{s,j} [W/m²]		Window area A _{w,j} [m²]	Total transmittance g _j [-]	I _{s,j} * (1 - F _f) * 0,9 * 0,9 * A _{w,j} * g _j [W]	
42	south-east to south-west	20		19,80	1,04	96,74	
43							
44	north-west to north-east	20		9,90	1,04	48,37	
45							
46	other directions	50		13,20	1,04	161,24	
47				9,90	1,04	120,93	
48	Dormer window with slope < 30°	5					
49	Solar heat gains:		Φ _s = Σ (I _{s,j} * (1 - F _f) * A _{w,j} * g _j)				Φ _s = 427,27
3.2 Internal Heat Gains Φ_i [W]							
51	Number of occupants [-]:	no _o =	3,00				
52	Internal gains of occupants [W]:	Φ _{i,o} = no _o * Φ _{i,o}					
		Φ _{i,o} = 3,00 * 50,00		Φ _{i,o} = 150,00			
53	Spec. internal gains of equipment	Φ _{i,e} =	2,00				
54	Internal gains of equipment [W]:	Φ _{i,e} = Φ _{i,e} * A _N					
		Φ _{i,e} = 4,22 * 90,00		Φ _{i,e} = 379,80			

55	4. Other uses				
56	Spec. lighting power [W/m²]:	$p_l =$	5		
57	Lighting power [W]:	$P_l =$	$p_l * A_N$	$=$	$\Phi_{l,l}$
		$P_l =$	5,00 * 90,00	$P_l =$	450,00
58	Spec. ventilation power [Wh/m³]:	$p_v =$	0,1		
59	Ventilation power [W]:	$P_v =$	$p_v * V * n_d$		
		$P_v =$	0,10 * 600,00 * 0,40	$P_v =$	24,00

60	5. Heat demand Φ_h [W]			
61	Heat demand [W]:	$\Phi_h = (\Phi_T + \Phi_V) - (\Phi_s + \Phi_{i,o} + \Phi_{i,e} + \Phi_{i,l})$ $\Phi_h = 1.466,80 - 1.407,07$	$\Phi_h = 59,73$	
62	Specific heat demand [W/m ²]	$\Phi''_h = \Phi_h / A_N$ $\Phi''_h = 59,73 / 90,00$	$\Phi''_h = 0,66$	
63	6. Heat production and emission			
64	Generation / Conversion:	Condensing boiler ▼	Efficiency η_G [-] 0,95 Primary energy factor source F_P [-] 1,30 Quality factor of source $F_{q,s}$ [-] 0,95 Max. supply temperature $\theta_{s,max}$ [°C] 70,00 Auxiliary energy $p_{aux,ge}$ [W/kW _{heat}] 1,80 Auxiliary energy $p_{aux,ge,const}$ [W] 20,00 Part. environmental energy F_{renew} [-]	
65	Storage:	Small / day storage ▼	Heat loss / efficiency η_s [-] 0,95 Auxiliary energy $p_{aux,s}$ [W/kW _{heat}] 2,00 Solar fraction F_s [-]	
66	Distribution system:	Boiler position Outside envelope ▼ Insulation Good insulation ▼ Design temperature Middle (<50°C) ▼ Temperature drop Middle (<10K) ▼	Heat loss / efficiency η_D [-] 0,83 Auxiliary energy $p_{aux,D}$ [W/kW _{heat}] 3,35	
67	Emission system:	Air heating/cooling ▼	Inlet temperature θ_{in} [°C] 35,00 Return temperature θ_{ret} [°C] 25,00 Auxiliary energy $p_{aux,E}$ [W/kW _{heat}] 6,03 Max. heat emission $p_{heat,max}$ [W/m ²] 34,00 Heat loss / efficiency η_E [-] 0,95	
68	DHW production system:	Dwelling; same boiler as for heating system ▼	DHW demand V_W [l/pers d] 45,00 Efficiency $\eta_{G,DHW}$ [-] 0,90 Primary energy factor source $F_{P,DHW}$ [-] 1,30 Quality factor of source $F_{q,s,DHW}$ [-] 0,95	
69	7. Results of exergy calculation			
70	Quality factor room air [-]:	$F_{q,room} = 1 - T_e / T_i$ $F_{q,room} = 0,03$	$F_{q,room} = 0,03$	
71	Exergy load room [W]:	$Ex_{room} = \Phi_h * F_{q,room}$ $Ex_{room} = 59,73 * 0,03$	$Ex_{room} = 2,04$	
72	Heating temperature [°C]:	$\theta_{heat} = \Delta \log \theta / 2 + \theta_i$ $\theta_{heat} = 4,55 * 20,00$	$\theta_{heat} = 24,55$	
73	Quality factor air at heater [-]:	$F_{q,heater} = 1 - T_e / T_{heat}$ $F_{q,heater} = 0,05$	$F_{q,heater} = 0,05$	
74	Exergy load at heater [W]:	$Ex_{heat} = \Phi_h * F_{q,heater}$ $Ex_{heat} = 59,73 * 0,05$	$Ex_{heat} = 2,92$	
75	Heat loss emission [W]:	$\Phi_{loss,E} = \Phi_h * (1/\eta_E - 1)$ $\Phi_{loss,E} = 59,73 * 0,05$	$\Phi_{loss,E} = 3,14$	
76	Auxiliary energy emission [W]:	$P_{aux,E} = p_{aux,E} * \Phi_h$ $P_{aux,E} = 0,01 * 59,73$	$P_{aux,E} = 0,36$	
77	Exergy demand emission [W]:	$\Delta Ex_{emis} = \{ (\Phi_h + \Phi_{loss,E}) / (T_{in} - T_{ref}) \} * \{ (T_{in} - T_{ref}) - T_{ref} * \ln (T_{in} / T_{ref}) \}$ $\Delta Ex_{emis} = 6,29 * 0,66$	$\Delta Ex_{emis} = 4,14$	
78	Heat loss distribution [W]:	$\Phi_{loss,D} = (\Phi_h + \Phi_{loss,E}) * (1/\eta_D - 1)$ $\Phi_{loss,D} = 62,87 * 0,20551499$	$\Phi_{loss,D} = 12,92$	
79	Auxiliary energy distribution [W]:	$P_{aux,D} = p_{aux,D} * (\Phi_h + \Phi_{loss,E})$ $P_{aux,D} = 0,00 * 62,87$	$P_{aux,D} = 0,21$	
80	Exergy demand distribution [W]:	$\Delta Ex_{dis} = \{ \Phi_{loss,D} / \Delta T_{dis} \} * \{ (\Delta T_{dis} - T_{ref} * \ln (T_{dis} / T_{dis} - \Delta T_{dis})) \}$ $\Delta Ex_{dis} = 1,29 * 1,10$	$\Delta Ex_{dis} = 1,42$	
81	Heat loss storage [W]:	$\Phi_{loss,S} = (\Phi_h + \Phi_{loss,E} + \Phi_{loss,D}) * (1/\eta_S - 1)$ $\Phi_{loss,S} = 75,79 * 0,05$	$\Phi_{loss,S} = 3,99$	
82	Auxiliary energy storage [W]:	$P_{aux,S} = p_{aux,S} * (\Phi_h + \Phi_{loss,E} + \Phi_{loss,D})$ $P_{aux,S} = 0,00 * 75,79$	$P_{aux,S} = 0,15$	
83	Exergy demand storage [W]:	$\Delta Ex_{stor} = \{ \Phi_{loss,S} / \Delta T_{sto} \} * \{ \Delta T_{sto} - T_{ref} * \ln (T_{dis} + \Delta T_{dis} / T_{dis} + \Delta T_{dis} - \Delta T_{sto}) \}$ $\Delta Ex_{stor} = 1,33 * 0,44$	$\Delta Ex_{stor} = 0,58$	
84	Req. energy of generation [W]:	$\Phi_{ge} = (\Phi_h + \Phi_{loss,E} + \Phi_{loss,D} + \Phi_{loss,S}) * (1 - F_s) / \eta_B$ $\Phi_{ge} = 79,78 * 1,00 / 0,95$	$\Phi_{ge} = 83,98$	
85	Auxiliary energy generation [W]:	$P_{aux,ge} = p_{aux,ge} * (\Phi_h + \Phi_{loss,E} + \Phi_{loss,D} + \Phi_{loss,S}) + p_{aux,ge,const}$ $P_{aux,ge} = 0,00 * 79,78 + 20,00$	$P_{aux,ge} = 20,14$	
86	Exergy load generation [W]:	$Ex_{ge} = \Phi_{ge} * F_{q,s}$ $Ex_{ge} = 83,98 * 0,95$	$Ex_{ge} = 79,78$	
87	DHW energy demand [W]	$P_W = V_W * c_p * \rho * \Delta T * n_{o_o} / \eta_{G,DHW}$ $P_W = 2,19 * 147,00 / 0,90$	$P_W = 357,29$	
88	Exergy load plant [W]:	$Ex_{plant} = (P_i + P_v) * F_{q,electricity} + P_W * F_{q,s,DHW}$ $Ex_{plant} = 474,00 + 339,43$	$Ex_{plant} = 813,43$	
89	Req. primary energy input [W]:	$E_{prim,tot} = \Phi_{ge} * F_P + (P_i + P_v + \Sigma P_{aux}) * F_{P,electricity} + P_W * F_{P,DHW}$		

		$E_{\text{prim,tot}} =$	$109,17 + 1.276,75 + 464,48$	$E_{\text{prim,tot}} =$	$1.850,41$
90	Add. renew. energy input [W]:	$E_{\text{renew}} = \Phi_{\text{ge}} * F_{\text{renew}} + E_{\text{environment}}$		$E_{\text{renew}} =$	
91	Total exergy input [W]:	$Ex_{\text{tot}} = \Phi_{\text{ge}} * F_P * F_{q,S} + (P_i + P_v + \Sigma P_{\text{aux}}) * F_{P,\text{elec}} * F_{q,\text{elec}} + P_W * F_{P,\text{DHW}} * F_{q,S,\text{DHW}} + E_{\text{renew}} * F_{q,\text{renew}}$			
		$Ex_{\text{tot}} =$	$1.380,47 + 441,26 +$	$Ex_{\text{tot}} =$	$1.821,72$

¹⁾ 0.9 for shading and 0.9 for not orthogonal radiation

Results in key figures	total	per Area	per Volume
Energy input (primary and renewable energy + internal and solar gains)	3257,48 W	36,19 W/m ²	5,43 W/m ³
Energy quality of envelope (heat demand + internal and solar gains)	1466,80 W	16,30 W/m ²	2,44 W/m ³
Total exergy system efficiency (exergy demand room / total exergy input)	0,001118		
Exergy flexibility factor (exergy demand emission / total exergy input)	0,004074		



Error messages

Results of the calculation:




Figure 1: Exergy and energy flows through components




Figure 2: Exergy losses / consumption by components




Figure 3: Energy gains and losses




Figure 4: Exergy supply and demand

Authors:

Dietrich Schmidt
KTH Building Technology
Brinellvägen 34
S-10044 Stockholm
SWEDEN

Masanori Shukuya
Musashi Institute of Technology
1-28-1 Tamazutsumi Setagaya-ku
Tokyo 158-8557
JAPAN

Abdelaziz Hammache
Natural Resources Canada
1615 Lionel-Boulet
Varenes Quebec J3X 1S6
CANADA

Johann Zirngibl
CSTB - Energie
84 avenue Jean
F-77421 Marly
FRANCE

With kind support of

Kirsten Höttges; Dep. of Building Physics; University of Kassel; D-34109 Kassel; GERMANY